

OWN 214 8/71

C 1 6862

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT A18313

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
FILL IN THIS FORM COMPLETELY
COUNTY NUMBER W23613

DATE RECEIVED (WRA USE ONLY) 26 1976
DATE WELL COMPLETED 26 1976
DEPTH OF WELL 295
PERMIT NO. FROM "PERMIT TO DRILL WELL" 40-10-15K3
DRILLER'S IDENTIFICATION NO. 256

OWNER: Mary Homer, Inc.
STREET OR RFD: 6655 N. Dublin Road
POST OFFICE: Columbia, MD 21044

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING	FEET	CHECK IF WATER BEARING	
DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FROM	TO	
Dirt	0	6	
Soft Brn. Mica	6	33	
Soft Brn. Mica	33	34	X
Soft Brn. Mica	34	50	
Soft Brn. Mica	50	51	X
Blue Mica	51	69	
Brown Mica	69	70	X
Blue Mica	70	100	
Brown Mica	100	102	
Blue Mica	102	280	
Quartz	280	281	X
Blue Mica	281	295	

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES Y NO N
TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT CM BENTONITE CLAY BC
NO. OF BAGS 13 NO. OF POUNDS 1 222
GALLONS OF WATER 78
DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM 0 FT. TO 50 FT.
(ENTER 0 IF FROM SURFACE)

CASING RECORD

INSERT APPROPRIATE CODE BELOW
STEEL CO CONCRETE PL OT
MAIN CASING TYPE S 6 61
NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6 61
TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 61

OTHER CASING (IF USED)
DIAMETER (INCH) DEPTH (FEET) FROM TO

SCREEN RECORD

INSERT APPROPRIATE CODE BELOW
STEEL BR HO PL OT
SCREEN TYPE OR OPEN HOLE
EACH SCREEN 1 2 3 (SEQ. NO.) 6
DEPTH (NEAREST WHOLE FOOT) FROM 61 TO 295
SLOTSIZE 1. 2. 3.

CIRCLE APPROPRIATE BOXES

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
E ELECTRIC LOG OBTAINED
P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME Dana Kyker, Jr., II
TELESCOPE CASING 70 LOG INDICATOR 72 OTHER DATA AVAILABLE 74 75 76

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 5
PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 3
METHOD USED TO MEASURE PUMPING RATE Flowmeter
WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 47 (NEAREST FOOT) WHEN PUMPING 20 (NEAREST FOOT)
TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST) A AIR P PISTON T TURBINE C CENTRIFUGAL R ROTARY O OTHER (DESCRIBE BELOW) J JET S SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)
DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES Y NO N
CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31 35
PUMP HORSE POWER 37 41
PUMP COLUMN LENGTH (NEAREST FOOT) 43 47
CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT) + ABOVE - BELOW LAND SURFACE (NEAREST FOOT) 49 50 51

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

HEALTH