

WR-W-6 9/71

C 1 5539 SEQUENCE NO. (FOR USE ONLY)

STATE OF MARYLAND WATER RESOURCES ADMINISTRATION TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401 WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION. FILL IN THIS FORM COMPLETELY. COUNTY NUMBER

DATE OF COMPLETION 4/9/73 DATE WELL COMPLETED

DEPTH OF WELL 150 (TO NEAREST FOOT)

PERMIT NO. FROM "PERMIT TO DRILL WELL" 2A-73-0217 DRILLER'S IDENTIFICATION NO. 209

OWNER VINELLA L. V. STREET OR RD. 12631 CIRCLE DR POST OFFICE 20850

WELL LOG

Table with columns: FEET (FROM, TO), CHECKED BY, DESCRIPTION. Rows: Clay (0-10), Office Soil (10-35), Office Rock (35-150). Includes handwritten notes: 'just apr. 73', 'Case 38', 'just 30', '6 logs done right'.

WELL DESCRIPTION

GROUTING RECORD: YES (C), NO (N). TYPE OF GROUTING MATERIAL: CEMENT (EM), BENTONITE CLAY (BC). NO. OF BAGS: 6, NO. OF POUNDS: 540. GALLONS OF WATER: 20. DEPTH OF GROUT SEAL: 0-30.

CASING RECORD: MAIN CASING TYPE: 57, DIAMETER: 6, DEPTH: 38. OTHER CASING: NONE.

SCREEN RECORD: BRASS OR BRONZE (BR), DIAMETER: 2, DEPTH: 30.

DEPTH OF WELL: 150. DEPTH OF SCREEN: 30. SLOTTED SIZE: 2.

PUMPING TEST

HOURS PUMPED: 6. PUMPING RATE: 5 GPM. METHOD USED TO MEASURE PUMPING RATE: TIME. WATER LEVEL: 50. TYPE OF PUMPED USED: AIR.

PUMP INSTALLED: TYPE OF PUMP: AIR. CAPACITY: 30 GPM. PUMP HORSE POWER: 37. PUMP COLUMN LENGTH: 43.

LOCATION OF WELL ON LOT: HOUSE, FRONT. SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND FOR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

CIRCLE APPROPRIATE BOXES: A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED. E ELECTRIC LOG OBTAINED. TEST WELL CONVERTED TO PRODUCTION WELL. I HEREBY CERTIFY THAT I HAVE COMPLETED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL". SIGNATURE: Howard Dillon

DIAMETER OF SCREEN: 2. GRAVEL PACK: NONE. IF WELL DRILLED WAS A FLOWING WELL, CIRCLE BOX 68. DWA USE ONLY (NOT TO BE FILLED IN BY DRILLER): LOG INDICATOR.