

AVP _____

TP # 49

Br Org / m 0-16"
 RED SILT 16"-2'6"
 RED/TAN SAND (FINE) 2'6"-13'

LOT # 11

TP # 52

Br Org / m 0-16"
 Br / RED / 16"-4'
 YELLOW (Varnigated)
 Structure medium
 RED/TAN SAND (FINE) 4'-13'

TP # 50

Br Org / m 0-16"
 RED SILT 16"-2'6"
 RED TAN SAND (FINE) 2'6"-13'

TP # 53

Br Org / m 0-12"
 RED/Br SILT 12"-3'
 Structured Blocky
 RED/Br SILT 3-4'
 Structure medium
 RED/TAN SAND (FINE) 4'-13'

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2nd INCH	P/F/H
10/20/04	# 49	13'		VISUAL	UAL		P
	# 50	5'6" / 13'	1:05	1:08	1:11	3 min	P
	# 51	13'		VISUAL			P
	# 52	6' / 13'	12:41:30	12:45	12:50	5 min	P
	# 53	5' / 13'	12:29	12:31	12:33	2 min	P

TP # 51

Br Org / m 0-20"
 RED/Br SILT 20"-4'
 RED TAN SAND (FINE) 4'-13'

REMARKS _____

SANITARIAN LSheetley BACKHOE AEC OTHERS _____

TEST HOLES USED IN SDA _____ AVG. PERC TIME _____ SQ. FT/BR _____

TRENCH WIDTH _____ INLET DEPTH _____ MAX. BOT DEPTH _____ EFFECTIVE SW _____