

SITE INSPECTION SHEET

OWNER: Linda Lorraine Megehee PHONE #: \_\_\_\_\_


ADDRESS: 15920 Meadow Walk CONTRACTOR: \_\_\_\_\_

WELL TAG #: HO-94-0829

SUBDIVISION: Daisy Hill Estates LOT: 20 COUNTY #: Howard

PROPOSAL: Site visit to confirm the location and condition of the septic and well on property.

LOCATION DIAGRAM



COMMENTS: The condition of the well is good and up to code. The well is above grade and is located 100 + feet from the dry well and septic tank. The septic tank could not be opened to be observed. The drywell was visibly full and appears as if it had not been pumped. There was no evidence of surface failure and the entire area surrounding the septic tank and drywell was free from any standing water. After review of the records at the Howard County Health Department, it was observed that the system was installed in 1972. Most septic systems have a 20-30 year lifespan.

DATE: 1-17-12

INSPECTOR: Dana Bernard, REHS/RS



MARYLAND DEPARTMENT OF THE ENVIRONMENT

1800 Washington Boulevard • Baltimore MD 21230

410-537-3000 • 1-800-633-6101

Robert L. Ehrlich, Jr.  
Governor

Kend P. Philbrick  
Secretary

Michael S. Steele  
Lt. Governor

Jonas A. Jacobson  
Deputy Secretary

October 5, 2005

**CERTIFIED MAIL - 7001 2510 0002 9975 5470**  
**Return Receipt Requested**

COLUMBIA ASSOCIATION, INC.  
10221 WINCOPIN CIR  
STE 100  
COLUMBIA, MD 21044-3410

RE: State Water Appropriation  
Permit No. HO1992S010(02)  
Revision 02

Dear Permittee:

Enclosed is your State Water Appropriation Permit. The permittee is responsible for complying with all permit conditions. Accordingly, you are advised to carefully read the Permit and become thoroughly familiar with its requirements.

Semi-annual Water Withdrawal Reports are required by this permit. Forms for making these reports will be mailed to you in June and December of each year.

If you have any questions, please contact this office at (410) 537-3590.

Sincerely,

MARK T. FILAR  
Water Supply Program

cc: HOWARD COUNTY HEALTH DEPARTMENT

**STATE OF MARYLAND**  
**DEPARTMENT OF THE ENVIRONMENT**  
**WATER MANAGEMENT ADMINISTRATION**

**WATER APPROPRIATION AND USE PERMIT**

PERMIT NUMBER: HO1992S010(02)

EFFECTIVE DATE: OCTOBER 1, 2005

EXPIRATION DATE: OCTOBER 1, 2017

FIRST APPROPRIATION: SEPTEMBER 1, 1993



COLUMBIA ASSOCIATION, INC.

HEREINAFTER REFERRED TO AS THE "PERMITTEE", IS AUTHORIZED BY THE WATER MANAGEMENT ADMINISTRATION, HEREINAFTER REFERRED TO AS THE "ADMINISTRATION" PURSUANT TO THE PROVISIONS OF TITLE 5 OF THE ENVIRONMENT ARTICLE, ANNOTATED CODE OF MARYLAND (1996 REPLACEMENT VOLUME) AS AMENDED, TO APPROPRIATE AND USE WATERS OF THE STATE SUBJECT TO THE FOLLOWING CONDITIONS:

1. ALLOCATION - THE WATER WITHDRAWAL GRANTED BY THIS PERMIT IS LIMITED TO:  
A DAILY AVERAGE OF 45,000 GALLONS ON A YEARLY BASIS AND  
A MAXIMUM DAILY WITHDRAWAL OF 250,000 GALLONS.
2. USE - THE WATER IS TO BE USED FOR IRRIGATION AT THE FAIRWAY HILLS GOLF COURSE.
3. SOURCE - THE WATER SHALL BE TAKEN FROM THE LITTLE PATUXENT RIVER.
4. LOCATION - THE POINT(S) OF WITHDRAWAL SHALL BE LOCATED ABOUT 400 FEET SOUTH OF MD ROUTE 108, 600 FEET WEST OF COLUMBIA ROAD, 0.2 MILE WEST OF U.S. ROUTE 29, HOWARD COUNTY, MARYLAND

CONTINUED ON PAGE 2

5. RIGHT OF ENTRY - THE PERMITTEE SHALL ALLOW AUTHORIZED REPRESENTATIVES OF THE ADMINISTRATION ACCESS TO THE PERMITTEE'S FACILITY TO CONDUCT INSPECTIONS AND EVALUATIONS NECESSARY TO ASSURE COMPLIANCE WITH THE CONDITIONS OF THIS PERMIT. THE PERMITTEE SHALL PROVIDE SUCH ASSISTANCE AS MAY BE NECESSARY TO EFFECTIVELY AND SAFELY CONDUCT SUCH INSPECTIONS AND EVALUATIONS.
6. PERMIT REVIEW - THE PERMITTEE WILL BE QUERIED EVERY THREE YEARS (TRIENNIAL REVIEW) REGARDING WATER USE UNDER THE TERMS AND CONDITIONS OF THIS PERMIT. FAILURE TO RETURN THE TRIENNIAL REVIEW QUERY WILL RESULT IN SUSPENSION OR REVOCATION OF THIS PERMIT.
7. PERMIT RENEWAL - THIS PERMIT WILL EXPIRE ON THE DATE INDICATED ON THE FIRST PAGE OF THIS PERMIT. IN ORDER TO RENEW THE PERMIT THE PERMITTEE SHALL FILE A RENEWAL APPLICATION WITH THE ADMINISTRATION NO LATER THAN 45 DAYS PRIOR TO THE EXPIRATION.
8. PERMIT SUSPENSION OR REVOCATION - THIS PERMIT MAY BE SUSPENDED OR REVOKED BY THE ADMINISTRATION UPON VIOLATION OF THE CONDITIONS OF THIS PERMIT, OR UPON VIOLATION OF ANY REGULATION PROMULGATED PURSUANT TO TITLE 5 OF THE ENVIRONMENT ARTICLE, ANNOTATED CODE OF MARYLAND (1996 REPLACEMENT VOLUME) AS AMENDED.
9. CHANGE OF OPERATIONS - ANY ANTICIPATED CHANGE IN APPROPRIATION WHICH MAY RESULT IN A NEW OR DIFFERENT USE, QUANTITY, SOURCE, OR PLACE OF USE OF WATER SHALL BE REPORTED TO THE ADMINISTRATION BY THE PERMITTEE BY SUBMISSION OF A NEW APPLICATION.
10. ADDITIONAL PERMIT CONDITIONS - THE ADMINISTRATION MAY AT ANYTIME (INCLUDING TRIENNIAL PERMIT REVIEW OR WHEN A CHANGE APPLICATION IS SUBMITTED) REVISE ANY CONDITION OF THIS PERMIT OR ADD ADDITIONAL CONDITIONS CONCERNING THE CHARACTER, AMOUNT, MEANS AND MANNER OF THE APPROPRIATION OR USE, WHICH MAY BE NECESSARY TO PROPERLY PROTECT, CONTROL AND MANAGE THE WATER RESOURCES OF THE STATE. CONDITION REVISIONS AND ADDITIONS WILL BE ACCOMPLISHED BY ISSUANCE OF A REVISED PERMIT.


11. DROUGHT PERIOD EMERGENCY RESTRICTIONS - IF THE DEPARTMENT DETERMINES THAT A DROUGHT PERIOD OR EMERGENCY EXISTS, THE PERMITTEE MAY BE REQUIRED UNDER THE DEPARTMENT'S DIRECTION TO STOP OR REDUCE WATER USE. ANY CESSATION OR REDUCTION OF WATER USE MUST CONTINUE FOR THE DURATION OF THE DROUGHT PERIOD OR EMERGENCY, OR UNTIL THE DEPARTMENT DIRECTS THE PERMITTEE THAT WATER USE UNDER STANDARD PERMIT CONDITIONS MAY BE RESUMED.
12. NON-TRANSFERRABLE - THIS PERMIT IS NON-TRANSFERRABLE. A NEW OWNER MAY ACQUIRE AUTHORIZATION TO CONTINUE THIS APPROPRIATION BY FILING A NEW APPLICATION WITH THE ADMINISTRATION. AUTHORIZATION WILL BE ACCOMPLISHED BY ISSUANCE OF A NEW PERMIT.
13. FLOW MEASUREMENT - THE PERMITTEE SHALL MEASURE ALL WATER USED UNDER THIS PERMIT BY A METHOD WHICH SHALL BE APPROVED BY THE ADMINISTRATION.
14. WITHDRAWAL REPORTS - THE PERMITTEE SHALL SUBMIT TO THE ADMINISTRATION, SEMI-ANNUALLY (JULY-DECEMBER, NO LATER THAN JANUARY 31 AND JANUARY-JUNE, NO LATER THAN JULY 31), PUMPING RECORDS. THESE RECORDS SHALL SHOW THE TOTAL QUANTITY OF WATER PUMPED EACH MONTH UNDER THIS PERMIT.
15. PERMIT SUPERSESSION - THIS PERMIT HAS BEEN REVIEWED AND REVISED AND SUPERSEDES THE APPROPRIATION AND USE GRANTED BY THE FOLLOWING PRIOR PERMIT ISSUED TO:  
COLUMBIA ASSOCIATION, INC. ON SEPTEMBER 1, 1993  
(HO1992S010(01))

16 FLOW-BY - IN ORDER FOR WITHDRAWALS TO BE MADE UNDER THIS PERMIT, THE FOLLOWING QUANTITIES OF WATER MUST BE AVAILABLE AS FLOW-BY IMMEDIATELY DOWNSTREAM OF THE PERMITTEE'S WITHDRAWAL POINT DURING THE INDICATED PERIODS OF TIME:

A.DURING THE PERIOD JUNE 1 THROUGH OCTOBER 31, A CONTINUOUS FLOW-BY OF AT LEAST 5.3 CUBIC FEET OF WATER PER SECOND OF TIME (CFS) (2380 GPM) SHALL BE MAINTAINED DOWNSTREAM OF THE INTAKE:

B.DURING THE PERIOD NOVEMBER 1 THROUGH MAY 31, A CONTINUOUS FLOW-BY OF AT LEAST 11.8 CFS (5316 GPM) SHALL BE MAINTAINED DOWNSTREAM OF THE INTAKE. ALL FLOW-BY MEASURING DEVICES AND THEIR LOCATIONS SHALL BE APPROVED BY THE ADMINISTRATION.

BY AUTHORITY OF THE DIRECTOR  
WATER MANAGEMENT ADMINISTRATION

 10/11/05  
\_\_\_\_\_  
John W. Grace, Chief  
SOURCE PROTECTION AND APPROPRIATION DIV

PERMIT NO.: HO1992S010(02) ACTID: 199282606 September 13, 2005

APPLICANT: COLUMBIA ASSOCIATION, INC.  
REMARKS: COLUMBIA ASSOCIATION, INC. - FAIRWAY HILLS GOLF  
COURSE  
PROJECT DESC: COLUMBIA ASSOCIATION, INC.

WATER TYPE: F REPORT CODE: Y  
AQUIFER TEST: N WQ ANALYSIS: N

ADC MAP: 15 J 2  
MD GRIDS: NORTH 511000 EAST 0843000  
TAX MAP NO.: 30 BLOCK NO.: 8,9,14,15 PARCEL: 439& 397 SBDN  
BLOCK: LOT:  
CO GEO-HYDRO MAP: L USGS TOPO: SAVAGE

SUB-BASIN: 02-13-11-05 STREAM CODE: LXT AQUIFER CODE:  
WATER USE: CODE 1 CODE 2 CODE 3 CODE 4  
| 203 100.0 | 0.0 | 0.0 | 0.0 |

INTAKES: INTAKE ID N GRID E GRID USE PERCENT

CARBON COPIES:

SUPPLEMENTAL/RELATED (S/R):

SECONDARY NAMES: