



Fredericktowne Labs Inc.

ENVIRONMENTAL TESTING

3020 Ventrie Court * P.O. Box 245 * Myersville, MD 21773 * 301-293-3340 * Fax 301-293-2366
 www.fredericktownelabs.com * info@fredericktownelabs.com

Certificate of Analysis

Acct. No. 3948 - 1158-1

Field Record

REVISED
 Address 9/19/14

Site visit performed on: Wednesday, September 10, 2014 2:55 PM
 by: Kevin Kretzer State ID No. 1511KK
 Affiliation: Tri-County Pump Service
 Property Owner: Craft Mark Homes
 Project: Lot 65
 Property Address: 5005 Lindera Court
 Ellicott City, MD
 Sample Source: Kitchen Sink
 Treatment Devices Noted: No Treatment Devices
 Sample taken after treatment: No
 Well No.: HO-95-2358
 Field pH: 6.6
 Total Res. Cl.: 0.0 mg/l

Laboratory Report

Sample Received at laboratory: 9/11/2014 8:00 AM

Inorganic Chemical results:

| Parameter | Result Units | MCL | Date of Analysis | Method | Analyst |
|------------------|--------------|-----|------------------|---------------|---------|
| Nitrate-Nitrogen | 3.9 mg/l | 10 | 9/11/2014 | 300.0 | PH |
| Nitrite Nitrogen | <0.2 mg/l | 1 | 9/11/2014 | 300.0 | PH |
| Sand | <2 mg/l | 5 | 9/11/2014 | 0.065mmFilter | KB |
| Turbidity | 0.6 NTU | 10 | 9/11/2014 | 180.1 | KB |

OK
 9/28/15 sc

Reported by: Callie Mellott 9/19/14
 Name Date

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
 Maryland Cert. No. 118 Virginia Cert. No. 00444
 MDOT WBE Cert. No.: 91-158