



3
 217
 5

 1085

 31
 37.0
 2.5

 1850
 7800

 9250

SEPTIC TANK LEVEL 2,000
 CLEANOUTS C.O. at S.T. & House OK
 DISTRIBUTION BOX LEVEL OK, baffle is in place.
 DRAIN FIELD/TILE FIELD DEPTH 8 1/2 FT TRENCH WIDTH 2 FT INLET DEPTH 3 1/2 FT.
 EFFECTIVE GRAVEL DEPTH 5 FT TOTAL LENGTH 50, 51, 49, 67 = 217 FT
 NUMBER OF TRENCHES 4 ~~SIDEWALL~~ AREA 1085 SQ. FT.
 DRYWELL INSIDE DIAMETER _____ FT EFFECTIVE DEPTH BELOW INLET _____ FT
 ABSORBENT AREA 1085 SQ. FT.

REMARKS [6-11-90] S.P. and sewer line from house O.K. [6-12-90]
1+2 trenches OK to cover BDA [6-13-90] 2+3 trenches
O.K. to stone BDA 6-14-90 system is O.K. to cover

DATE SYSTEM APPROVED 6/14/96 INSPECTOR Barry D. Adams