

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 94547 Account #: 1930
 Reference: Fogle's Well Drilling Company: Fogle's Well Drilling
 Location: 2720 Florence Rd Requested By: Dave Fogle
 Woodbine, MD 21797 Source: Well Water
 Date/ Time Collected: 6/6/2014 0945 Site: Kitchen Sink
 Date/Time Rec'd: 6/6/2014 1130 Treatment: None
 Chlorine ppm: Free: ND Total: ND pH: 7.1
 Collected By: J. Fogle 1974JF Well #: HO-95-2485

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	6/7/2014 / 1015 / LLO
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	6/7/2014 / 1015 / LLO
Nitrate	4.71	mg/L	10	601	6/6/2014 / 1310 / CRS
Turbidity	0.77	NTU	<10	SM18 2130B	6/6/2014 / 1225 / JKW
Sand	NS	mg/L	5	Visual/Gravimetric	6/6/2014 / 1225 / JKW

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 NS = None Seen (NS indicates less than 5 mg/L)
- 4 NTU = Nephelometric Turbidity Units
- 5 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 6 ND:None Detected
- 7 Sample collected by client, analyzed as received
- 8 pH tested in lab, chlorine level tested on site

Reason for Test : Use & Occupancy**Building Permit # :** B13001258Date Reported: 6/9/2014