



Bureau of Environmental Health
7178 Columbia Gateway Drive Columbia, MD 21046
(410) 313-2640 Fax (410) 313-2648
TDD (410) 313-2323 Toll Free 1-866-313-6300
website: www.hchealth.org

Peter L. Beilenson, M.D., M.P.H., Health Officer

May 27, 2010

Homeowner
5556 Landing Road
Elkridge, MD 21075

RE: 5556 Landing Road
Elkridge, MD 21075
BP #: B09000408

Dear Sir:

This is to advise you that the septic system for the above referenced property has been installed and inspected. **Final approval of the septic system was granted on 5/5/2010 by HCHD. Final approval of the well line connection to the dwelling was approved on 5/25/2010.**

The water sample results indicate that the water samples submitted for testing were free of coliform and fecal coliform bacteria at the time of sampling and are bacteriologically safe for drinking.

INTERIM CERTIFICATE OF OCCUPANCY

The Health Department does not guarantee water supplies. Based upon test results and inspections, the Howard County Health Department recommends Use and Occupancy of the above dwelling.

This certificate may become final upon completion of the second bacteriological test, which is to be taken by the county health department within six months of receipt of this letter. Please contact (410) 313-1773 to schedule a final water sample appointment. Currently, there is no charge for this final sampling.

Date of Water Sample: 5/17/2010

Approving Authority,

Brian Baker, R. S.
Well & Septic Program

cc: Building Inspector's Office
Community Health Services
File