

CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: May 25, 2004

County Howard

Lab Number 04-2409

Sample iced Yes
Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. Yes

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality
Laboratory No. 115

REQUESTER: Bella Donna Homes
Attn: Sal Migliore
115 Ridgely Avenue
Annapolis, Maryland 21401

Property Sampled: U&O: 13190 Clarksville Pike

Station Sampled: Powder room tap

Date/Time Sampled: May 24, 2004 11:30 am

Owner, Telephone No.:

Subdivision Name:

Building Permit No.: B00139857

Well Number: HQ-94-3520

Tax Map #:

Parcel #:

Sampler: 67246P

Lot Number:

Observation: 2-Piece Cap
Satisfactory

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	<1.0 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	1.2 NTU	EPA 180.1	*10 NTU	Pass
pH	6.9 Units	EPA 150.1	**6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	*Absent	SAFE
E. coli (18 Hour Test)	Absent	SM 9223B	*Absent	SAFE

Treatment/Conditioning: None

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, odor, or color) in drinking water.

Sharon K. Cassell

*MCL = Maximum Contamination Level
**SMCL = Secondary Maximum Contamination Level