

CASSELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality
Laboratory No. 115

REQUESTER: Mr. Jim Hess
644 River Road
Sykesville, Maryland 21784

Rental

REPORT DATE: Jan 20, 2005

County Howard

Lab Number 05-0325

Sample iced Yes

Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. Yes

Property Sampled: 11008 Harding Road

Station Sampled: Hall Bathroom Tap

Date/Time Sampled: Jan 19, 2005 11:10 am

Owner, Telephone No.: Hess

Subdivision Name: Coon Manor

Building Permit No.:

Well Number: HO-81-2091

Tax Map #: 46

Parcel #: 168

Sampler: 67246P

Lot Number: 2

Observation: 1-Piece Cap
CAP REMOVABLE
Rope between
cap & casing

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	6.8 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	<1.0 NTU	EPA 180.1	*10 NTU	Pass
pH	6.0 Units	EPA 150.1	**6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	*Absent	SAFE
E. coli	Absent	SM 9223B	*Absent	SAFE

Treatment/Conditioning: NONE

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, odor, or color) in drinking water.

Heather R. Beam

Heather R. Beam

*MCL = Maximum Contamination Level
**SMCL = Secondary Maximum Contamination Level