

CASSELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: Aug 5, 2004

County Howard

Lab Number 04-4003

Sample iced Yes

Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. Yes

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality

Laboratory No. 115

REQUESTER:

Selfridge Builders
Attn: Doug
14045 Gared Drive
Glenwood, Maryland 21738

Property Sampled: U&O: 3219 Huntersworth Way

Station Sampled: Pressure tank tap

Date/Time Sampled: Aug 4, 2004 12:30 pm

Owner, Telephone No.: Gorman

Subdivision Name: The Woods Of Wellington

Building Permit No.: B00145413

Well Number: HO-94-2977

Tax Map #: 14

Parcel #: 264

Sampler: 6724GP

Lot Number: 21

Observation: 2-Piece Cap
Satisfactory

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	<1.0 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	8.5 NTU	EPA 180.1	*10 NTU	Pass
pH	5.9 Units	EPA 150.1	**6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	*Absent	SAFE
E. coli	Absent	SM 9223B	*Absent	SAFE

Treatment/Conditioning: None

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, odor, or color) in drinking water.

Heather R. Beam

Heather R. Beam

*MCL = Maximum Contamination Level

**SMCL = Secondary Maximum Contamination Level