

CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: Aug 17, 2004

County Howard

Lab Number 04-4317

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality
Laboratory No. 115

REQUESTER: Selfridge Builders
Attn: Doug
14045 Gared Drive
Glenwood, Maryland 21738

Sample iced Yes
Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. Yes

Property Sampled: U&O: 3246 Huntersworth Way

Station Sampled: Powder Room Tap

Tax Map #:

Date/Time Sampled: Aug 16, 2004 12:50 pm

Parcel #:

Owner, Telephone No.: Fagan

Sampler: 6724GP

Subdivision Name: Woods Of Wellington

Lot Number: 15

Building Permit No.: B00145412

Well Number: HD-94-2971

Observation: 2-Piece Cap
Cap Tight
2 Bolts Missing

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	1.3 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	2.2 NTU	EPA 180.1	*10 NTU	Pass
pH	5.4 Units	EPA 150.1	**6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	*Absent	SAFE
E. coli	Absent	SM 9223B	*Absent	SAFE

Treatment/Conditioning: NONE

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, odor, or color) in drinking water.

Heather R. Beam

Heather R. Beam

*MCL = Maximum Contamination Level

**SMCL = Secondary Maximum Contamination Level