

# CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING  
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211  
(410) 252-7742

REPORT DATE: Sep 9, 2004  
County: Howard  
Lab Number: 04-4811  
Sample iced: Yes  
Residual Cl<sub>2</sub> <0.1 mg/L: Yes  
cc: County Health Dept.: Yes

## CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality  
Laboratory No. 115

REQUESTER: Temple Isaiah  
Attn: Barbara Rubin  
12200 Scaggsville Road  
Fulton, Maryland 20759

Property Sampled: U&O: 12200 Scaggsville Road, Follow-up Test

Station Sampled: Break Room Tap

Tax Map #: 41

Date/Time Sampled: Sep 8, 2004 11:45 am

Parcel #: 2

Owner, Telephone No.:

Sampler: 6724GP

Subdivision Name: Cecil Cole Property

Lot Number: 4

Building Permit No.: B00141039

Well Number: HQ-94-3601

Observation: 2-Piece Cap  
Satisfactory

### RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL
pH	6.1 Units	EPA 150.1	**6.5-8.5 Units ***
Total Coliform	Absent	SM 9223B	*Absent SAFE
E. coli	Absent	SM 9223B	*Absent SAFE

SEP 15 14 00

*Sharon K. Cassell*  
Sharon K. Cassell

\*MCL = Maximum Contamination Level  
\*\*SMCL = Secondary Maximum Contamination Level

