

CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: Oct 14, 2004

County Howard

Lab Number 04-5500

Sample iced Yes

Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. Yes

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality
Laboratory No. 115

REQUESTER: Selfridge Builders
Attn: Doug
14045 Gared Drive
Glenwood, Maryland 21738

Property Sampled: U&O: 3517 Winding Path Court, retest #1

Station Sampled: Pressure tank tap

Tax Map #:

Date/Time Sampled: Oct 13, 2004 9:30 am

Parcel #:

Owner, Telephone No.: Conley

Sampler: 67246P

Subdivision Name: Cattail Ridge

Lot Number: 26

Building Permit No.: B0014627B

Well Number: HO-94-2429

Observation: 2-Piece Cap
Cap tight
1 Bolt Missing
1 bolt loose

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Total Coliform	Absent	SM 9223B	*Absent	SAFE
E. coli (18 Hour Test)	Absent	SM 9223B	*Absent	SAFE

Treatment/Conditioning: NONE

3007 OCT 18 AM 8:11

ENVIRO...
RECEIVED

Heather R. Beam

Heather R. Beam

*MCL = Maximum Contamination Level

**SMCL = Secondary Maximum Contamination Level

CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: Sep 11, 2004

County Howard

Lab Number 04-4855

Sample iced Yes

Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. Yes

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality

Laboratory No. 115

REQUESTER:

Selfridge Builders
Attn: Doug
14045 Gared Drive
Glenwood, Maryland 21738

Property Sampled: U&O: 3517 Winding Path Court

Station Sampled: Pressure tank tap

Date/Time Sampled: Sep 10, 2004 10:10 am

Owner, Telephone No.: Conley

Subdivision Name: Cattail Ridge

Building Permit No.: B00146278

Well Number: HO-94-2429

Tax Map #:

Parcel #:

Sampler: 67246P

Lot Number: 26

Observation: 2-Piece Cap
Cap tight
1 Bolts Missing
1 bolt loose

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	2.8 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	4.5 NTU	EPA 180.1	*10 NTU	Pass
pH	6.0 Units	EPA 150.1	**6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	PRESENT	SM 9223B	*Absent	UNSAFE
E. coli (18 Hour Test)	Absent			

Treatment/Conditioning: NONE

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, odor, or color) in drinking water.

Sharon K. Cassell

*MCL = Maximum Contamination Level

**SMCL = Secondary Maximum Contamination Level