

CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: Feb 24, 2006

County Howard

Lab Number 06-2442

Sample iced Yes

Residual Cl₂ <0.1 mg/L Yes

cc: County Health Dept. No

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality
Laboratory No. 115

REQUESTER: Mr. Michael L. Peterson
6962 Pindell School Road
Fulton, Maryland 20759

Property Sampled: 6962 Pindell School Road

Station Sampled: Pressure Tank

Tax Map #:

Date/Time Sampled: Feb 23, 2006 9:55 am

Parcel #:

Owner, Telephone No.:

Sampler: 67246P

Subdivision Name:

Lot Number:

Building Permit No.:

Well Number: HO-88-0327

Observation: 2-Piece Cap
Satisfactory**RESULTS OF ANALYSIS:**

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	<1.0 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Total Coliform E. coli	PRESENT Absent	SM 9223B	*Absent	UNSAFE

Treatment/Conditioning: UV Light, Sediment Filter, Neutralizer, Softener
Bypassed

*MCL = Maximum Contamination Level
**SMCL = Secondary Maximum Contamination Level



Laura T. Fedor