

# CERTIFICATE OF ANALYSIS



Trace Laboratories, Inc.  
Maryland

5 North Park Drive  
Hunt Valley, MD 21030  
Telephone: 410/252-7742  
Telephone: 410/584-9099  
Fax: 410/584-9117  
Email: [tracelab@connext.net](mailto:tracelab@connext.net)  
[www.tracelabs.com](http://www.tracelabs.com)

Maryland State Certified  
Water Quality Laboratory  
No. 318

ISO 9001:2000



PERRY JOHNSON  
REGISTRARS, INC.

Cert No. C2005-01504

**Requester:**  
West Friendship Center LLC  
c/o Bayview Management  
17 West Pennsylvania Avenue Suite 500  
Towson, Maryland 21204

**S/O Number:** 66109  
**Report Date:** November 15, 2007

**Property Sampled:** 12800 Frederick Road, 4<sup>th</sup> Quarter

**County:** Howard  
**UIN#:** 113-0015  
**Tax Map #:** N/A  
**Parcel #:** N/A

**Date/Time Collected:** November 14, 2007 at 11:02 am  
**Date/Time Received:** November 14, 2007 at 2:45 pm

**Sample Location:** Liquor Store Tap  
**Sampler ID:** 6308KW  
**Samples Iced:** Yes  
**Residual Cl<sub>2</sub> <0.1 mg/L:** Yes

**Well Tag Number:** Tag not visible  
**Well Condition:** Well not observed  
Well condition undetermined

**Water Conditioning/Treatment:** UV Light, Softener, Carbon Tanks, Soda Ash System  
(Not Observed)

PARAMETER	RESULT	METHOD	MCL	
Nitrate	11.3 mg/L as N	SM 4500D	10 mg/L as N	High
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn  
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

# CERTIFICATE OF ANALYSIS

**Requester:**  
West Friendship Center LLC  
c/o Bayview Management  
17 West Pennsylvania Avenue Suite 500  
Towson, Maryland 21204

**S/O Number:** 66109  
**Report Date:** November 27, 2007



**Trace Laboratories, Inc.**  
Maryland

5 North Park Drive  
Hunt Valley, MD 21030  
Telephone: 410/252-7742  
Telephone: 410/584-9099  
Fax: 410/584-9117  
Email: [tracelab@connext.net](mailto:tracelab@connext.net)  
[www.tracelabs.com](http://www.tracelabs.com)

Maryland State Certified  
Water Quality Laboratory  
No. 318

ISO 9001:2000



Cert No. C2005-01504

**Property Sampled:** 12800 Frederick Road, Arsenic, 4<sup>th</sup> Quarter

**County:** Howard  
**UIN#:** 113-0015  
**Tax Map #:** N/A  
**Parcel #:** N/A

**Date/Time Collected:** November 14, 2007 at 11:02 am  
**Date/Time Received:** November 14, 2007 at 2:45 pm

**Sample Location:** Liquor Store Tap  
**Sampler ID:** 6308KW  
**Samples Iced:** Yes  
**Residual Cl<sub>2</sub> <0.1 mg/L:** Yes

**Well Tag Number:** Tag not visible  
**Well Condition:** 2-Piece Cap  
Satisfactory

**Water Conditioning/Treatment:** UV Light, Softener, Carbon Tanks, Soda Ash System

PARAMETER	RESULT	METHOD	MCL
Arsenic+	<0.003 mg/L	EPA 200.8	0.010 mg/L

+Analyzed by Lab #273.

Allison R. Milburn  
Manager-Drinking Water Testing

MCL=Maximum Contamination Level