

CERTIFICATE OF ANALYSIS



Requester:
Trinity Homes/TBI Homes
3675 Park Avenue Suite 301
Ellicott City, Maryland 21043

S/O Number: 07-1416
Report Date: August 1, 2006

Property Sampled: 7014 Guilford Road, Retest #2

County: Howard
Subdivision: N/A
Lot #: 17
Building Permit #: B00150315

Tax Map #: N/A
Parcel #: N/A

Date/Time Collected: July 31, 2006 at 11:15 am
Date/Time Received: July 31, 2006 at 1:55 pm

Sample Location: Powder Room Tap
Sampler ID: 6724GP
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

*Summer Prof
8/7*

Well Tag Number: HO-94-3763
Well Condition: 2-Piece Cap
Satisfactory

Water Conditioning/Treatment: None

PARAMETER	RESULT	METHOD	MCL	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Heather R. Beam
Heather R. Beam
Manager-Drinking Water Testing