

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.
 1415 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #:	66260	Account #:	1930
Reference:	Richard Lepore	Company:	Fogle's Well Drilling
Location:	4850 Greenbridge Road Dayton, MD 21036	Requested By:	Dave Fogle
Date/ Time Collected:	1/3/2008 0900	Source:	Well Water
Date/Time Rec'd:	1/3/2008 1536	Site:	Kitchen Sink Tap
Chlorine ppm:	Free: ND Total: ND	Treatment:	None
Collected By:	V.M. Fadoul 6804VF-FS	pH:	6.3
		Well #:	HO-95-1367

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	1/4/2008 / 0955 / AD/BD
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	1/4/2008 / 0955 / AD/BD
Nitrate	<1.0	mg/L	10	601	1/3/2008 / 1545 / AD/BD
Turbidity	1.35	NTU	<10	SM18 2130B	1/3/2008 / 1545 / AD/BD
Sand	NS	mg/L	5	Visual/Gravimet	1/3/2008 / 1545 / AD/BD

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 NS = None Seen (NS indicates less than 5 mg/L)
- 4 NTU = Nephelometric Turbidity Units
- 5 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 6 ND:None Detected
- 7 Sample collected by client, analyzed as received
- 8 pH tested on-site

Reason for Test : HoCo New Well

Date Reported: 1/7/2008