



Requester:
 Catonsville Builders
 11175 Stratfield Court
 Marriottsville, Maryland 21104

S/O Number: 67652
Report Date: March 25, 2008

Property Sampled: 1398 Underwood Road, 21784

County: Howard
Subdivision: N/A **Tax Map #:** N/A
Lot #: N/A **Parcel #:** N/A
Building Permit #: B06000866

Date/Time Collected: March 24, 2008 at 10:53 am
Date/Time Received: March 24, 2008 at 12:10 pm

Sample Location: Laundry Tub Tap **Samples Iced:** Yes
Sampler ID: 6308KW **Residual Cl₂ <0.1 mg/L:** Yes

Well Tag Number: HO-95-0361
Well Condition: 2-Piece Cap
 Satisfactory

Water Conditioning/Treatment: None

PARAMETER	RESULT	METHOD	MCL/*SMCL	
Nitrate	6.1 mg/L as N	SM 4500D	10 mg/L as N	Pass
Turbidity	<1.0 NTU	EPA 180.1	10 NTU	Pass
pH	5.6 Units	EPA 150.1	*6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn
 Allison R. Milburn
 Manager-Drinking Water Testing

MCL=Maximum Contamination Level
 *SMCL=Secondary Maximum Contamination Level
 ***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, color or odor) in drinking water.