

CERTIFICATE OF ANALYSIS

Requester:
Mr. Richard Azrael
5850 Waterloo Road
Suite 230
Columbia, Maryland 21045

S/O Number: 64056-2
Report Date: June 27, 2007



Trace Laboratories, Inc.
Maryland

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connext.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Property Sampled: 14337 Burntwoods Road – Site #3 – Retest

County: Howard
Subdivision: N/A
Lot #: 6

Tax Map #: N/A
Parcel #: N/A

Date/Time Collected: June 26, 2007 at 10:31 am
Date/Time Received: June 26, 2007 at 3:10 pm

Sample Location: Pump
Sampler ID: 6308KW
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: HO-95-1094
Well Condition: N/A

Water Conditioning/Treatment: N/A

PARAMETER	RESULT	METHOD	MCL	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level