

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1011 (410) 876-3554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #:	65302	Account #:	2359
Reference:	Pakmail	Company:	Holland Properties
Location:	2490 Route 97	Requested By:	Joe Holland
	Cooksville, MD 21723	Source:	Well Water
Date/ Time Collected:	10/1/2007 1110	Site:	Pressure Tank
Date/Time Rec'd:	10/1/2007 1250	Treatment:	Softener/Neutralizer**
Chlorine ppm:	Free: ND Total: ND	pH:	7.1
Collected By:	J.Yeager 6176JY	Well #:	HO-94-3438

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	10/2/2007 / 0815 / AD/BD
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	10/2/2007 / 0815 / AD/BD
Nitrate	8.57	mg/L.	10	601	10/1/2007 / 1310 / AD/BD
Turbidity	0.78	NTU	<10	SM18 2130B	10/2/2007 / 0755 / AD/BD
Sand	NS	mg/L.	5	Visual/Gravimct	10/2/2007 / 0755 / AD/BD

NOTES

- 1 **Sample collected prior to treatment
- 2 mg/L = milligrams per liter (also, parts per million)
- 3 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 4 NS = None Seen (NS indicates less than 5 mg/L)
- 5 NTU = Nephelometric Turbidity Units
- 6 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 7 ND:None Detected
- 8 Visual well check: Sealed, vented cap
- 9 pH tested on-site

Reason for Test : Use & Occupancy

Building Permit # : B060043

Date Reported: 10/2/2007