

# CERTIFICATE OF ANALYSIS



Trace Laboratories, Inc.  
Maryland

5 North Park Drive  
Hunt Valley, MD 21030  
Telephone: 410/252-7742  
Telephone: 410/584-9099  
Fax: 410/584-9117  
Email: [tracelab@connext.net](mailto:tracelab@connext.net)  
[www.tracelabs.com](http://www.tracelabs.com)

Maryland State Certified  
Water Quality Laboratory  
No. 318

ISO 9001:2000



Cert No. C2005-01504

**Requester:**  
Mr. Doug Waddell  
James H. Selfridge Builders, Inc  
4781 Ten Oaks Road  
Dayton, Maryland 21036

**S/O Number:** 65370  
**Report Date:** September 27, 2007

**Property Sampled:** 13603 Fox Stream Way, 21794, Retest #1

**County:** Howard  
**Subdivision:** Fox Meadow  
**Lot #:** 5  
**Building Permit #:** Not Provided  
**Tax Map #:** 15  
**Parcel #:** 167

**Date/Time Collected:** September 26, 2007 at 1:00 pm  
**Date/Time Received:** September 26, 2007 at 3:05 pm

**Sample Location:** Pressure Tank Tap  
**Sampler ID:** 6308KW  
**Samples Iced:** Yes  
**Residual Cl<sub>2</sub> <0.1 mg/L:** Yes

**Well Tag Number:** HO-94-3716  
**Well Condition:** 2-Piece Cap  
Satisfactory

**Water Conditioning/Treatment:** Neutralizer, Softener, Sediment Filter

PARAMETER	RESULT	METHOD	MCL	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn  
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

# CERTIFICATE OF ANALYSIS



Trace Laboratories, Inc.  
Maryland

5 North Park Drive  
Hunt Valley, MD 21030  
Telephone: 410/252-7742  
Telephone: 410/584-9099  
Fax: 410/584-9117  
Email: tracelab@connext.net  
www.tracelabs.com

Maryland State Certified  
Water Quality Laboratory  
No. 318

ISO 9001:2000



Cert No. C2005-01504

**Requester:**  
Mr. Doug Waddell  
James H. Selfridge Builders, Inc  
4781 Ten Oaks Road  
Dayton, Maryland 21036

**S/O Number:** 65202  
**Report Date:** September 14, 2007

**Property Sampled:** 13603 Fox Stream Way, 21794

**County:** Howard  
**Subdivision:** Fox Meadow  
**Lot #:** 5  
**Building Permit #:** Not Provided  
**Tax Map #:** 15  
**Parcel #:** 167

**Date/Time Collected:** September 13, 2007 at 12:57 pm  
**Date/Time Received:** September 13, 2007 at 3:00 pm

**Sample Location:** Pressure Tank  
**Sampler ID:** 6308KW  
**Samples Iced:** Yes  
**Residual Cl<sub>2</sub> <0.1 mg/L:** Yes

**Well Tag Number:** HO-94-3716  
**Well Condition:** 2-Piece Cap  
Satisfactory

**Water Conditioning/Treatment:** Neutralizer, Softener, Sediment Filter

PARAMETER	RESULT	METHOD	MCL/*SMCL	
Nitrate	8.5 mg/L as N	SM 4500D	10 mg/L as N	Pass
Turbidity	1.9 NTU	EPA 180.1	10 NTU	Pass
pH	5.9 Units	EPA 150.1	*6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	PRESENT	SM 9223B	Absent	Fail
E.coli	Absent	SM 9223B	Absent	

Allison R. Milburn  
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

\*SMCL=Secondary Maximum Contamination Level

\*\*\*A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, color or odor) in drinking water.