

**FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.**

1413 Old Towne Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-6298

**REPORT OF ANALYSIS**

Laboratory ID #:	64504	Account #:	1930
Reference:	Ron Ricks	Company:	Fogle's Well Drilling
Location:	13505 Highland Road Clarksville, MD 21029	Requested By:	Dave Fogle
Date/ Time Collected:	7/16/2007 1051	Source:	Well Water
Date/Time Rec'd:	7/16/2007 1439	Site:	Pressure Tank
Chlorine ppm:	Free: ND Total: ND	Treatment:	Neutralizer/ Softener**
Collected By:	J.Yeager 6176JY	pH:	5.5
		Well #:	HO-95-0483

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Gross Alpha	10.0	pCi/L	15	900.0	7/18/2007 / 1221 / MJN
Gross Beta	10.6	pCi/L	50	900.0	7/18/2007 / 1221 / MJN

**NOTES**

- 1 \*\*Sample collected prior to treatment
- 2 Gross Alpha Detection Limit: 1.3pC/L
- 3 Gross Beta Detection Limit: 1.3pCi/L
- 4 pCi/L = picocuries per liter
- 5 pH tested on-site
- 6 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 7 ND:None Detected
- 8 Visual well check: Sealed, vented cap
- 9 Subcontracted to Reference Lab #278

Reason for Test : Use & Occupancy  
 Building Permit # : B06003406

Date Reported: 7/31/2007

**FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.**

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

**REPORT OF ANALYSIS**

Laboratory ID #:	64505	Account #:	1930
Reference:	Ron Ricks	Company:	Fogle's Well Drilling
Location:	13505 Highland Road Clarksville, MD 21029	Requested By:	Dave Fogle
Date/ Time Collected:	7/16/2007 1051	Source:	Well Water
Date/Time Rec'd:	7/16/2007 1439	Site:	Kitchen Sink Tap
Chlorine ppm:	Free: ND Total: ND	Treatment:	Neutralizer/ Softener
Collected By:	J.Yeager 6176JY	pH:	6.9
		Well #:	HO-95-0483

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Gross Alpha	2.0	pCi/L	15	900.0	7/18/2007 / 1330 / MJN
Gross Beta	2.9	pCi/L	50	900.0	7/18/2007 / 1330 / MJN

**NOTES**

- Gross Alpha Detection Limit: 1.7 pCi/L
- Gross Beta Detection Limit: 1.3 pCi/L
- pCi/L = picocuries per liter
- pH tested on-site
- Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- ND:None Detected
- Visual well check: Sealed, vented cap
- Subcontracted to Reference Lab #278

Reason for Test : Use & Occupancy  
 Building Permit # : B06003406

Date Reported: 7/31/2007