

CERTIFICATE OF ANALYSIS

Requester:

Mr. Richard Azrael
Chateau Builders
5850 Waterloo Road
Suite 230
Columbia, Maryland 21045

S/O Number: 64056-3**Report Date:** June 27, 2007

Henry Prop
P-A

**Trace Laboratories, Inc.
Maryland**

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connext.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000

Cert No. C2005-01504

Property Sampled: 14337 Burntwoods Road – Site #2 – Retest**County:** Howard**Subdivision:** N/A**Tax Map #:** N/A**Lot #:** N/A**Parcel #:** N/A**Date/Time Collected:** June 26, 2007 at 10:51 am**Date/Time Received:** June 26, 2007 at 3:10 pm**Sample Location:** House - Pump**Sampler ID:** 6308KW**Samples Iced:** Yes**Residual Cl₂ <0.1 mg/L:** Yes**Well Tag Number:** HO-95-1095**Well Condition:** N/A**Water Conditioning/Treatment:** N/A

PARAMETER	RESULT	METHOD	MCL/*SMCL	
Total Coliform	PRESENT	SM 9223B	Absent	FAIL
E.coli	Absent	SM 9223B	Absent	

Allison R. Milburn
Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

CERTIFICATE OF ANALYSIS



Trace Laboratories, Inc.
Maryland

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connect.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Requester:
Mr. Richard Azrael
5850 Waterloo Road
Suite 230
Columbia, Maryland 21045

S/O Number: 64265-2
Report Date: July 11, 2007

Property Sampled: 14337 Burntwoods Road – Site #2 – Retest

County: Howard
Subdivision: N/A
Lot #: N/A
Tax Map #: N/A
Parcel #: N/A

Date/Time Collected: July 10, 2007 at 11:29 am
Date/Time Received: July 10, 2007 at 3:00 pm

Sample Location: House - Pump
Sampler ID: 6308KW
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: HO-95-1095
Well Condition: N/A

Water Conditioning/Treatment: N/A

PARAMETER	RESULT	METHOD	MCL	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level