

CERTIFICATE OF ANALYSIS



Requester:
Nicole Tiede
CT Contracting
1720 Saint Michael's Road
Woodbine, Maryland 21797

S/O Number: 63829
Report Date: June 12, 2007

Trace Laboratories, Inc.
Maryland

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connex.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Property Sampled: 2873 Florence Road, 21797

Florence Prop.

County: Howard
Subdivision: Woodbine
Lot #: 1
Building Permit #: Not provided

Tax Map #: 7
Parcel #: 155

Date/Time Collected: June 11, 2007 at 10:40 am
Date/Time Received: June 11, 2007 at 1:40 pm

Sample Location: Powder Room Tap
Sampler ID: 6308KW
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: No tag
Well Condition: 2-Piece Cap
Satisfactory

Water Conditioning/Treatment: None

PARAMETER	RESULT	METHOD	MCL/*SMCL	
Nitrate	3.8 mg/L as N	SM 4500D	10 mg/L as N	Pass
Turbidity	1.5 NTU	EPA 180.1	10 NTU	Pass
pH	5.1 Units	EPA 150.1	*6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

*SMCL=Secondary Maximum Contamination Level

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, color or odor) in drinking water.