

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #:	62376	Account #:	1930
Reference:	Jason McDonald	Company:	Fogle's Well Drilling
Location:	12573 Scaggsville Road Highland, MD 20777	Requested By:	Dave Fogle
Date/ Time Collected:	3/5/2007 1000	Source:	Well Water
Date/Time Rec'd:	3/5/2007 1345	Site:	Pressure Tank
Chlorine ppm:	Free: ND Total: ND	Treatment:	Softener/ Neutralizer**
Collected By:	V.M. Fadoul 6804VF-FS	pH:	6.3
		Well #:	HO-95-0531

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	3/6/2007 / 0810 / AD/BD
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	3/6/2007 / 0810 / AD/BD
Nitrate	6.80	mg/L	10	601	3/6/2007 / 1330 / BCD
Turbidity	15.2	NTU	<10	SM18 2130B	3/6/2007 / 0830 / AD/BD
Sand	Trace	mg/L	5	Visual/Gravimet	3/6/2007 / 0830 / AD/BD
Iron	1.26	mg/L	0.3	FR, 45 (126)	3/6/2007 / 0845 / AD/BD

NOTES

- **Sample collected prior to treatment
- mg/L = milligrams per liter (also, parts per million)
- MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- NS = None Seen (NS indicates less than 5 mg/L)
- NTU = Nephelometric Turbidity Units
- Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- ND:None Detected
- Sample collected by client, analyzed as received
- pH tested on-site

Reason for Test : HoCo- Replacement Well

Date Reported: 3/6/2007

MD State Certification # 133