

CERTIFICATE OF ANALYSIS



Requester:
Dr. Ellen Gaske
High Road Academy
12350 Hall Shop Road
Fulton, Maryland 20759

S/O Number: 63467
Report Date: May 17, 2007

Trace Laboratories, Inc.
Maryland

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connex.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Property Sampled: 12350 Hall Shop Road, 2nd Quarter

County: Howard **Tax Map #:** N/A
UIN#: 113-0033 **Parcel #:** N/A

Date/Time Collected: May 16, 2007 at 9:10 am

Date/Time Received: May 16, 2007 at 2:00 pm

Sample Location: Men's Bathroom Tap

Sampler ID: 6308KW

Samples Iced: Yes

Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: HO-92-0340

Well Condition: 2-Piece Cap
Satisfactory

Water Conditioning/Treatment: Not Observed

PARAMETER	RESULT	METHOD	MCL	
Nitrate	3.3 mg/L as N	SM 4500D	10 mg/L as N	Pass
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn
Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level