

CERTIFICATE OF ANALYSIS



**Trace Laboratories, Inc.
Maryland**

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connext.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Requester:
NV Homes, Inc
Attn: Brandon
6085 Marshalee Drive Suite 130
Elkridge, Maryland 21075

S/O Number: 62797
Report Date: April 6, 2007

Property Sampled: 14855 Union Chapel Road, 21797

County: Howard
Subdivision: Mew Woods
Lot #: 1
Building Permit #: N/A
Tax Map #: 14
Parcel #: 154

Date/Time Collected: April 5, 2007 at 9:00 am
Date/Time Received: April 5, 2007 at 2:30 pm

Sample Location: Bathroom Tap
Sampler ID: 6308KW
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: HO-94-4027
Well Condition: 2-Piece Cap
Satisfactory

Water Conditioning/Treatment: Sediment Filter

PARAMETER	RESULT	METHOD	MCL/*SMCL	
Nitrate	9.0 mg/L as N	SM 4500D	10 mg/L as N	Pass
Turbidity	<1.0 NTU	EPA 180.1	10 NTU	Pass
pH	6.8 Units	EPA 150.1	*6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

Allison R. Milburn
 Manager- Drinking Water Testing

MCL=Maximum Contamination Level

*SMCL=Secondary Maximum Contamination Level

***A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, color or odor) in drinking water.