

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1044 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #:	61289	Account #:	3123
Reference:	National Water Servicing	Company:	National Water Servicing
Location:	418 Brighton Dam Road	Requested By:	Dave Rycke
	Brookeville, MD 20833	Source:	Well Water
Date/ Time Collected:	11/9/2006 1100	Site:	Pressure Tank
Date/Time Rec'd:	11/9/2006 1236	Treatment:	Softener/Sediment Filter/Neutralizer**
Chlorine ppm:	Free: ND Total: ND	pH:	7.0
Collected By:	J.Yeager 6176JY	Well #:	N/A

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYS
Bacteria, Coliform, Total, MPN	73.8	MPN/ 100 ml	<1.0	SM18 9223 B.	11/10/2006 / 0815 / AD/BD
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	11/10/2006 / 0815 / AD/BD
Nitrate	<1.0	mg/L	10	601	11/10/2006 / 1000 / BCD
Turbidity	13.5	NTU	<10	SM18 2130B	11/10/2006 / 0900 / AD/BD
Sand	NS	mg/L	5	Visual/Gravimetric	11/10/2006 / 0900 / AD/BD

NOTES

- 1 **Sample collected prior to treatment
- 2 mg/L = milligrams per liter (also, parts per million)
- 3 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 4 N/A - Not Available, Cap at or below grade
- 5 NS = None Seen (NS indicates less than 5 mg/L)
- 6 NTU = Nephelometric Turbidity Units
- 7 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 8 ND:None Detected
- 9 Visual well check: Sealed, vented cap
- 10 pH tested on-site

Reason for Test : Use & Occupancy
 Building Permit # : 434788

Date Reported: 11/10/2006