

CERTIFICATE OF ANALYSIS



Requester:
National Water Service
PO Box 138
Ashton, Maryland 20861

S/O Number: 66000
Report Date: November 8, 2007

Trace Laboratories, Inc.
Maryland

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connex.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Property Sampled: 12060 Open Run Road

County: Howard
Subdivision: Riverwood
Lot #: 19
Building Permit #: Not Provided

Tax Map #: 29
Parcel #: 20

Date/Time Collected: November 7, 2007 at 10:57 am
Date/Time Received: November 7, 2007 at 3:26 pm

Sample Location: Basement Tap After Treatment
Sampler ID: 6308KW
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: HO-94-4051
Well Condition: 2-Piece Cap
Satisfactory

Water Conditioning/Treatment: Neutralizer, Softener, Sediment Filter, Carbon Filter,
Nitrate Removal System

PARAMETER	RESULT	METHOD	MCL
Nitrate	11.5 mg/L as N	SM 4500D	10 mg/L as Fail

Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

CERTIFICATE OF ANALYSIS



Requester:
National Water Service
PO Box 138
Ashton, Maryland 20861

S/O Number: 66044
Report Date: November 12, 2007

**Trace Laboratories, Inc.
Maryland**

5 North Park Drive
Hunt Valley, MD 21030
Telephone: 410/252-7742
Telephone: 410/584-9099
Fax: 410/584-9117
Email: tracelab@connext.net
www.tracelabs.com

Maryland State Certified
Water Quality Laboratory
No. 318

ISO 9001:2000



Cert No. C2005-01504

Property Sampled: 12060 Open Run Road

County: Howard
Subdivision: Riverwood
Lot #: 19
Building Permit #: Not Provided
Tax Map #: 29
Parcel #: 20

Date/Time Collected: November 9, 2007 at 11:30 am
Date/Time Received: November 9, 2007 at 1:23 pm

Sample Location: Basement Tap After Treatment
Sampler ID: 6308KW
Samples Iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

Well Tag Number: HO-94-4051
Well Condition: 2-Piece Cap
Satisfactory

Water Conditioning/Treatment: Neutralizer, Softener, Sediment Filter, Carbon Filter,
Nitrate Removal System

PARAMETER	RESULT	METHOD	MCL	
Nitrate	1.6 mg/L as N	SM 4500D	10 mg/L as	Pass

Allison R. Milburn
Manager-Drinking Water Testing

MCL=Maximum Contamination Level