

Environmental Testing Lab Inc.

108 Old Solomons Island Rd
Annapolis, MD 21401



3430 Rockefeller Ct
Waldorf, MD 20602

State Certified Water Quality
Laboratory # 106

State Certified Water Quality
Laboratory # 139

REPORT OF ANALYSIS

Tim Shotzberger
Home Land Septics
308 Liberty Road
Baltimore, MD 21221

Lab Number: 75811
Date Received: 2/19/08 13:45
Project:

Sample No: 75811-01

Sampled: 2/19/2008 12:00:00 PM

Client ID: Toll Brothers
Triadelphia Crossing,
Lot #2
Gelenig, MD

Sampler: 8065TS Shotzberger

14311 Roxbury Lake Dr.

Parameter	Method	Result	Units	MDL	Test Date	Analyst
Bacteria-Total Coliform	SM 9223	Absent/PASS	Per/100ml	1	2/19/2008	LH
Clarity	Visual	Clear			2/21/2008	
Nitrate + Nitrite as N	EPA 353.2	* 10.8	mg/l	0.05	2/20/2008	PM
Sand	Visual	0	g/L		2/21/2008	
Turbidity	EPA 180.1	< 0.5	NTU	0.5	2/20/2008	PM
Bacteria-E.coli	SM 9223	Absent/PASS	Per/100ml	1	2/19/2008	LH
Nitrite-N	EPA 353.2	< 0.05	mg/l	0.05	2/20/2008	PM
Nitrate-N	EPA 353.2	10.8	mg/l	0.05	2/20/2008	PM

Notes:

- 75811-01 Maximum Contaminate Level in Drinking Water for Nitrate+Nitrite is 10.0 mg/L, Nitrate-N 10.0 mg/L and Nitrite-N 1.0 mg/L as established by the US EPA.
- 75811-01 No chlorine present at the time of collection as reported by the sample collector.

Reviewed and Approved by:

Daniel J. Brunsted
Laboratory Director

Hb Co. (410) 313-2648