

95157

PERMIT

P 13124

SEWAGE DISPOSAL SYSTEM

A 12977

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

INDEXED

DISTRICT 3

DATE 9/28/67

Lindy L. Dell IS PERMITTED TO INSTALL X ALTER

ADDRESS 3507 Spaulding Ave., Baltimore, Md. PHONE 367-0808

A SEWAGE DISPOSAL-SYSTEM LOCATED AT _____

SUBDIVISION _____ ROAD Rt. 144 nr. Rt. 32 LOT #1

PROPERTY OWNER Lindy L. & Carrie L. Dell

ADDRESS _____

SPECIFICATIONS - 4 bedrooms

DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

SEEPAGE PITS _____ ABSORBENT SIDE-WALL AREA _____ SQ. FT.

SEPTIC TANK CAPACITY 1,000 GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 22% & TANK CAPACITY 50%.

OTHER Dry well - 125 sq. ft. per bedroom located 99 ft. from right rear corner of existing large shed and 81 ft. from right side of existing wire fence as seen when facing lot from Rt. 144. Maximum depth 15 ft. - 9-20-85 - NO EVIDENCE OF FAILURE - SUFFICIENT AREA FOR REPAIR - NO VISUAL HOLE REQUIRED. S. Abel

PERMIT VOID AFTER THREE YEARS.

PLANS APPROVED BY J. H. Kilmore DATE 9/28/67

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTIFY THE HEALTH DEPARTMENT 48 HOURS BEFORE EXCAVATIONS ARE TO BE BACK FILLED.

STATE OF MARYLAND

**HOWARD COUNTY HEALTH DEPARTMENT
ELLICOTT CITY, MARYLAND**

Date 9/28/1967

Name Carrie P. Bell

Telephone No. 367-0808

DETAILED LOCATION OF SITE, DEVELOPMENT,
SECTION, ROAD, LOT NO. & ELECTION DISTRICT 3
Judy P. & Carrie Bell
Rt. 32 nr. Rt. 144

PRIVATE SEWAGE DISPOSAL SYSTEMS

Testing and Inspection \$ _____

Installation Permit \$ 5⁰⁰

Received Jub
Payment _____

ORIGINAL 13124
12977

THIS RECEIPT IS NOT
A PERMIT AND IT IS
NOT A WARRANTY OF
PERFORMANCE OF
THE SYSTEM THAT
IS INSTALLED