



3525 H Ellicott Mills Drive, Ellicott City, MD 21043
(410) 313-2640 Fax (410) 313-2648
TDD (410) 313-2323 Toll Free 1-866-313-6300
website: www.hchealth.org

Penny E. Borenstein, M.D., M.P.H., Health Officer

September 14, 2004

MEMORANDUM

TO: Tim Ragen
Selfridge Builders
14045 Gared Drive
Glenwood, MD 21738

FROM: Brian Baker, R.S.
Well & Septic Program
Bureau of Environmental Health

RE: 12118 Frederick Road
Tax Map 16, Grid 13, Parcel 23

This is to advise that the Howard County Health Department recommends issuance of the requested demolition permit for the referenced property. The following will be done at some time during the demolition process.

The existing well on the property will be located and then protected until it is sealed by a licensed well driller. A scavenger truck will pump out the existing septic tank and drywell and then they will be filled with dirt or another suitable material. Documentation showing that the drywell and septic tank have been abandoned and that the well has been sealed will be submitted to the health department.

Cc: File