

LAYOUT 8/26/09 INSP 4 \_\_\_\_\_  
 INSP 2 8/27/09 INSP 5 \_\_\_\_\_  
 INSP 3 \_\_\_\_\_ INSP 6 \_\_\_\_\_

ISSUE DATE: 8-20-09 **PERMIT** P 531887

APPROVAL DATE: 9/17/09 *In Pat Trac* A 531021  
 Tax ID # 03289974

**ON-SITE SEWAGE DISPOSAL SYSTEM  
 HOWARD COUNTY HEALTH DEPARTMENT  
 BUREAU OF ENVIRONMENTAL HEALTH**

FOGLES IS PERMITTED TO INSTALL  ALTER

ADDRESS: \_\_\_\_\_ PHONE NUMBER: \_\_\_\_\_

SUBDIVISION: Rosenbloom Property LOT NUMBER: 5

ADDRESS: 3838 Folly Quarter Road PROPERTY OWNER: James Rosenbloom

SEPTIC TANK CAPACITY (GALLONS): 2000 OUTLET BAFFLE FILTER REQUIRED

PUMP CHAMBER CAPACITY (GALLONS): \_\_\_\_\_ COMPARTMENTED TANK REQUIRED

NUMBER OF BEDROOMS: 6 APPLICATION RATE: 0.8

SQUARE FOOTAGE OF HOUSE: \_\_\_\_\_ *Inlet 2'*

LINEAR FEET OF TRENCH REQUIRED: 240 210' *Bottom 4.5'*

TRENCHES:	Trenches to be 3.0 feet wide. Inlet 2.0 feet below original grade. Bottom maximum depth 4.0 feet below grade. Effective area begins at 2.0 feet below original grade. 2.0 feet of stone below distribution pipe.
LOCATION:	1. Set distribution box at the top of the septic easement. 2. Install (4) 60 foot trenches on contour at the highest point of the septic easement.
NOTES:	1. Stake septic easement corners and addition corners for layout inspection. 2. Call for layout inspection. 3. Gravel tickets must be available for Environmental Sanitarians.

PLANS APPROVED: Dana Bernard DATE: 8/13/09

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

**NEITHER THE HOWARD COUNTY COUNCIL OR THE HEALTH DEPARTMENT IS  
 RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM  
 PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT  
 CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM**

NOT TO SCALE

See As-Built Drawing  
On Separate Sheet

ROAD NAME

TRENCH/DRAINFIELD DATA

WIDTH 3 INLET 2'-2.5' BOTTOM 4.5-5'

NUMBER OF TRENCHES 3

TOTAL LENGTH 217'

ABSORPTION AREA 651 + Sidewall

DISTRIBUTION BOX LEVEL Levelers

DISTRIBUTION BOX BAFFLE Yes

DISTRIBUTION BOX PORT Yes

SEPTIC TANK DATA

SEPTIC TANK I LEVEL Yes

MANUFACTURER Baby/On

CAPACITY 2000 GAL

SEAM LOC Top

TANK LID DEPTH 0.5-1'

BAFFLES Yes

BAFFLE FILTER No

MANHOLE LOC Front+Rear

6" PORT LOC None

WATERTIGHT TEST No

SLOTTED Yes

DATE ON LID 8/7/09

PUMP/SEPTIC TANK LEVEL N/A

MANUFACTURER

CAPACITY GAL

SEAM LOC

TANK LID DEPTH

BAFFLES

BAFFLE FILTER

MANHOLE LOC

6" PORT LOC

WATERTIGHT TEST

SLOTTED

DATE ON LID

PRE-CONSTRUCTION:

8/26/09 Install three 70' trenches on contour across the highest part of the easement. Put the new tank near one of the top easement corners. Top trench location marked in field. Keep septic tank out of well radius. (BB)

8/27/09 No one at site. No work done. (BB)

9/17/09 System finished. Plogles to pump out and fill in drywell and septic tank. O.K. to backfill. Top trench is 6" deeper. (BB)

FINAL INSPECTOR

B. Baker

DATE OF APPROVAL

9/17/09

NOT TO SCALE

