

C 1 2361 SEQUENCE NO. (WRA USE ONLY)

1 2 3 4 5 6 (SEQ. NO.) 6  
 (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)

DATE RECEIVED (WRA USE ONLY) \_\_\_\_\_

DATE WELL COMPLETED 7/11/79

DEPTH OF WELL 160  
 22 (TO NEAREST FOOT) 26

PERMIT NO. FROM "PERMIT TO DRILL WELL"  
HAO-73-2107  
 28 29 30 31 32 33 34 35 36 37

DRILLERS IDENTIFICATION NO. \_\_\_\_\_

**STATE OF MARYLAND**  
**WATER RESOURCES ADMINISTRATION**  
**TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401**  
**\*WELL COMPLETION REPORT**

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION

**FILL IN THIS FORM COMPLETELY**

COUNTY NUMBER \_\_\_\_\_

OWNER REUWER, DONALD LAST NAME FIRST NAME

STREET OR RFD 5701 B HARRIS FARM POST OFFICE COLUMBIA, MD.

**WELL LOG**

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING
	FROM	TO	
Top Soil	0	2	
Sandy	2	20	
Clay	20	90	
Hard Stone	90	110	
T.C.A.	110	160	

**GROUTING RECORD**

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES  NO

TYPE OF GROUTING MATERIAL (CIRCLE BOX):  
 CEMENT  BENTONITE CLAY

NO. OF BAGS 27 NO. OF POUNDS 2700

GALLONS OF WATER 135

DEPTH OF GROUT SEAL (TO NEAREST FOOT)  
 FROM 0 FT. TO 160 FT.  
 (ENTER 0 IF FROM SURFACE)

**CASING RECORD**

INSERT APPROPRIATE CODE BELOW

STEEL  CONCRETE   
 PLASTIC  OTHER

MAIN CASING TYPE 21 NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 99

**OTHER CASING (IF USED)**

EACH CASING	DIAMETER (INCH)		DEPTH (FEET)	
	FROM	TO	FROM	TO

**SCREEN RECORD**

INSERT APPROPRIATE CODE BELOW

STEEL  BRASS OR BRONZE  OPEN HOLE   
 PLASTIC  OTHER

**SCREEN**

DEPTH (NEAREST WHOLE FOOT) FROM TO

1	8	9	11	15	17	21
2	23	24	26	30	32	36
3	38	39	41	45	47	51

SLOT SIZE 1. \_\_\_\_\_ 2. \_\_\_\_\_ 3. \_\_\_\_\_

DIAMETER OF SCREEN \_\_\_\_\_ (NEAREST INCH)  
 FROM \_\_\_\_\_ TO \_\_\_\_\_

GRAVEL PACK \_\_\_\_\_

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX  68  F

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) (E.R.O.S.)

TELESCOPE CASING  LOG INDICATOR  W Q

**PUMPING TEST**

HOURS PUMPED (TO NEAREST HOUR) 3

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 8

METHOD USED TO MEASURE PUMPING RATE Bucket

WATER LEVEL: (DISTANCE FROM LAND SURFACE)  
 BEFORE PUMPING 30 (NEAREST FOOT) 20  
 WHEN PUMPING 160 (NEAREST FOOT) 25

TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST)

A AIR  P PISTON  T TURBINE   
 27 27 27  
 C CENTRIFUGAL  R ROTARY  O OTHER (DESCRIBE BELOW)   
 27 27 27  
 J JET  S SUBMERSIBLE   
 27 27

**PUMP INSTALLED**

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)  29

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES  NO

CAPACITY:  
 GALLONS PER MINUTE (TO NEAREST GALLON) 31 35  
 PUMP HORSE POWER 37 41  
 PUMP COLUMN LENGTH (NEAREST FOOT) 43 47

**CASING HEIGHT** (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE } LAND SURFACE  
 BELOW } 2 (NEAREST FOOT)  
 49 50 51

**LOCATION OF WELL ON LOT**

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

**CIRCLE APPROPRIATE BOXES**

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME \_\_\_\_\_

(PLEASE PRINT) L.P. Easterday

SIGNATURE L.P. Easterday



TAX MAP 22  
PARCEL 337  
HOWARD WILLIAM BAKER, SR.  
6126/292

3/26/07  
New Geo well  
Site's approval  
(New)

E 1,327.0  
N 577,950  
Neighbors  
well  
HO-73-1953

4 holes  
Closed Loop

New  
loop  
site

N89°50'00"E

366.25'

75' B.R.L.

PROPOSED 2.9' HIGH  
RETAINING WALL  
TOP OF WALL 430.90  
BOTTOM OF WALL 426.00

EXISTING WELL  
HO-73-2107

EXISTING HOUSE  
TO REMAIN  
FF-435.00  
426.5'

LOD.

329'

430

E 1,327.050

N 577,650

CLEANOUT

EXISTING SEPTIC  
TANK (TBR)

EX. CONCRETE  
POOL (TBR)

428

426

PARCEL 276  
5.00 AC±

CLEANOUT

CLEANOUT

SEPTIC EASEMENT

424

30' B.R.L.

60' B.R.L.

N04°43'34"E

S89°50'00"W

TAX MAP 22  
PARCEL 280  
CHARLES G. GADIZALA  
717/255

