

knoonan@mail.co.ho.md.us

Account Options...

Languages...

Menu	View Mail	Compose	Search	Calendar	Help	Log Off
------	-----------	---------	--------	----------	------	---------

Go Back | [Prev](#) | [Next](#) | [Reply](#) | [Reply All](#) | [Forward](#) | [Delete](#) | [Move To Deleted](#)

Message: 201 of 287 [Printable Version](#)

From: "Kacie Noonan" <knoonan@mail.co.ho.md.us> [Save Address](#) | [Headers](#)
 To: <Petitconstruct@aol.com>
 CC:
 Date: Tue, 8 Nov 2005 12:55:26 -0500
 Subject: **Re: septic field problem**

I received a written response from the Asistant Director, Bert Nixon. He wanted to bring to light that maybe its decomposed material buried to the point of collapse, or if its in the septic area that some escavation may be necessary to further assess what is in the ground. He wanted me to ask your "experience" for possible input or reasons.

Hope this enlightens you in your situation. Please keep us posted.
-kc

----- Original Message -----
 From: Petitconstruct@aol.com
 Date: Mon, 7 Nov 2005 08:52:14 EST

>Dear Kasey Noonan,
 >I tried explaining over the phone our situation, but you requested I send an email...
 >
 >We built our house 12 years ago at 7560 Greenwood Drive, Highland, MD 20777
 >Our property is 1 acre with the septic field in the back yard shaped like the letter "H".
 >The septic system was installed by Jack Fyock and inspected by your department.
 >Two years ago we saw a sink hole the size of a bath tub develop and didn't think
 >too much of it and filled it in. This summer another sink hole developed and is growing
 >larger. We called Fyock and was told "that's normal". We called the County and was refered to you.
 >>From my construction experience, I beleive I know why this happened and how to remedy
 >the problem. Please call me to discuss this matter.
 >Sincerely, C. B. Petit, Jr.
 >Home 301-854-9136
 >Work 301-854-2477
 >
 >

[Go Back](#) | [Prev](#) | [Next](#) | [Reply](#) | [Reply All](#) | [Forward](#) | [Delete](#) | [Move To Deleted](#) 

[Back to Top](#)

 Regular Mode Secure Mode	Classic WebMail Contact Webmail Support
--	---

From: Petitconstruct@aol.com
To: knoonan@mail.co.ho.md.us
CC:
Date: Tue, 27 Dec 2005 16:54:15 EST
Subject: **septic field**

12/27/05

Dear Kasey Noonan,

I have not heard from you since you canceled our appointment to inspect my septic field. Please give me a courtesy call to confirm your (or your associates) next appointment.

Thank you,

Boyd Petit

7560 Greenwood Drive

Highland, MD 20777

301-854-2477

From: Petitconstruct@aol.com
To: knoonan@mail.co.ho.md.us
CC:
Date: Thu, 29 Dec 2005 08:16:38 EST
Subject: **Re: septic field**

12/29/05

Jan. 3rd will be fine - please confirm a time.
Thanks, Boyd Petit

From: "Kacie Noonan" <knoonan@mail.co.ho.md.us>
To: <Petitconstruct@aol.com>
CC:
Date: Thu, 29 Dec 2005 08:02:44 -0500
Subject: **Re: septic field**

I wondered what happened. I have January 3rd avail. Do you want that date???

-kc

----- Original Message -----

From: Petitconstruct@aol.com
Date: Tue, 27 Dec 2005 16:54:15 EST

>12/27/05
>Dear Kasey Noonan,
>I have not heard from you since you canceled our appointment to inspect my
>septic field.
>Please give me a courtesy call to confirm your (or your associates) next
>appointment.
>Thank you,
>Boyd Petit
>7560 Greenwood Drive
>Highland, MD 20777
>301-854-2477
>
>

From: "Kacie Noonan" <knoonan@mail.co.ho.md.us>
To: <Petitconstruct@aol.com>
CC:
Date: Mon, 28 Nov 2005 12:20:04 -0500
Subject: **Re: Site inspection**

I am not able to get out this week due to staff shortage. Do you have pictures you can email me? I can see if another sanitarian can get out there.

-kc

----- Original Message -----

From: Petitconstruct@aol.com
Date: Tue, 22 Nov 2005 12:06:06 EST

>11/22/05

>noon

>Dear Kasey, The 28th is available. Email me the aprox. time or please call

>my cell phone that day to meet.

>Thanks, Boyd

>

>

From: "Kacie Noonan" <knoonan@mail.co.ho.md.us>
To: <Petitconstruct@aol.com>
CC:
Date: Fri, 18 Nov 2005 09:12:27 -0500
Subject: **Site inspection**

Bert Nixon said to head out for a site inspection. Please let me know if you have the 22nd avail or the 28th. I could possibly do it over the weekend during the holidays, if necessary.

-thanks
kc

From: "Kacie Noonan" <knoonan@mail.co.ho.md.us>
To: <Petitconstruct@aol.com>
CC:
Date: Wed, 9 Nov 2005 07:31:08 -0500
Subject: **Re: septic field problem**

I will bring this to my Assitant Director's attention immediately. It sounds I should pull your file and review it and see if and when we can come out to inspect and what actions need to be taken to correct the problem. I will contact you shortly. Please give me the address again so I may pull your file.

Thanks
kc

----- Original Message -----
From: Petitconstruct@aol.com
Date: Tue, 8 Nov 2005 17:36:47 EST

>11/8/05
>Dear Ms. Noonan,
>I'd like to speak to whichever one of you will be helping resolve this
>problem; but here
>are some basic facts.
>*The lot has a gentle grade (almost flat).
>*The system was installed in virgin soil, with trenches filled with gravel
>and the pvc pipe,
>then "red rosin paper" on top of the gravel, then a layer of native soil on
>top. NO other
>construction trash, debris, ashes, etc. was used for backfill.
>*The system seems to be working fine without any backups, and the tank has
>been
>emptied twice with no problems.
>
>I believe the paper has rotted and allowed the topsoil to filter down into
>the gravel trench.
>I saw this with the first, second, and now third sinkhole. You can actually
>see into the
>ends of the sinkhole and see a "cave" under the topsoil and above the dirt
>filled gravel.
>
>What can be done to resolve this problem?
>
>Thank you, Boyd Petit
>
>

FILE INQUIRY NOTES

DATE	RESULTS OF REVIEW FOR FILE
	upon Inspection of the sinkhole I believe it is the end of one of his his trenches. No signs of failure w/ system (EJB) 1-20-06