

C 1 1254 SEQUENCE NO. (MDE USE ONLY)

STATE OF MARYLAND
WELL COMPLETION REPORT
FILL IN THIS FORM COMPLETELY
PLEASE TYPETHIS REPORT MUST BE SUBMITTED WITHIN
45 DAYS AFTER WELL IS COMPLETED.COUNTY
NUMBER1 2 3 6
(THIS NUMBER IS TO BE PUNCHED
IN COLS. 3-6 ON ALL CARDS)

ST/CO USE ONLY

DATE Received

MM DD YY
12 05 11

DATE WELL COMPLETED

MM DD YY
08 30 11

Depth of Well

22 475 26
(TO NEAREST FOOT)PERMIT NO.
FROM "PERMIT TO DRILL WELL"28 29 30 31 32 33 34 35 36 37
40 95 - 2100OWNER CHELSEA RIDGE L.C.
WELL SITE ADDRESS last name LONG CORNER ROAD first name TOWN Mt. Airy
SUBDIVISION CHELSEA KNOLLS SECTION LOT 5

WELL LOG

Not required for driven wells

STATE THE KIND OF FORMATIONS PENETRATED, THEIR
COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (Use additional sheets if needed)	FEET		check if water bearing
	FROM	TO	
SOIL	0	7	
CLAY	7	12	
Brown shale	12	57	
Blue slate	57	475	✓
		80	✓
		450	✓

GROUTING RECORD

WELL HAS BEEN GROUTED
(Circle Appropriate Box)yes no
Y N
44 44

TYPE OF GROUTING MATERIAL (Circle one)

CEMENT CM BENTONITE CLAY BC

NO. OF BAGS 15 NO. OF POUNDS 1410

GALLONS OF WATER 90

DEPTH OF GROUT SEAL (to nearest foot)

from 48 TOP 52 ft. to 54 BOTTOM 58 ft.
(enter 0 if from surface)

CASING RECORD

casing
types
insert
appropriate
code
belowST
STEELCO
CONCRETEPL
PLASTICOT
OTHERMAIN
CASING
TYPENominal diameter
top (main) casing
(nearest inch)!Total depth
of main casing
(nearest foot)

PL

6

60

E
A
C
H
C
A
S
I
N
G

OTHER CASING (if used)

diameter
inchdepth (feet)
from toscreen type
or open hole

SCREEN RECORD

(insert
appropriate
code
below)ST
STEELBR
BRASSHO
OPEN
HOLEPL
PLASTICOT
OTHER

C 2

DEPTH (nearest ft.)

1 2

E 1

A 8

C 9

H 11

S 23

C 24

3 26

R 38

E 39

N 41

SLOT SIZE 1

2

3

DIAMETER
OF SCREEN

56

60

from

to

GRAVEL PACK
IF WELL DRILLED
WAS FLOWING WELL
INSERT F IN BOX 68MDE USE ONLY
(NOT TO BE FILLED IN BY DRILLER)

T

(E.R.O.S.)

W Q

70

72

TELESCOPE
CASINGLOG
INDICATOR

OTHER DATA

C 3

1 2

PUMPING TEST

HOURS PUMPED (nearest hour)

PUMPING RATE (gal. per min.)

METHOD USED TO
MEASURE PUMPING RATE

WATER LEVEL (distance from land surface)

BEFORE PUMPING

WHEN PUMPING

TYPE OF PUMP USED (for test)

A air P piston T turbine
C centrifugal R rotary O other
(describe below)
J jet S submersible

PUMP INSTALLED


DRILLER INSTALLED PUMP YES NO

IF DRILLER INSTALLS PUMP, THIS SECTION
MUST BE COMPLETED FOR ALL WELLS.TYPE OF PUMP INSTALLED
PLACE (A,C,J,P,R,S,T,O)
IN BOX 29.CAPACITY:
GALLONS PER MINUTE
(to nearest gallon)

PUMP HORSE POWER

PUMP COLUMN LENGTH
(nearest ft.)CASING HEIGHT (circle appropriate box
and enter casing height)+ above } LAND SURFACE
- below } (nearest foot)LATITUDE 39.31708
LONGITUDE 72.15580
(DEFAULT COORD. WGS 84)

NOTES: Prop Line



DRILLERS LIC. NO. 1 MWD 355

DRILLERS SIGNATURE
(MUST MATCH SIGNATURE ON APPLICATION)

LIC. NO. 1 MSD 066

SITE SUPERVISOR (sign. of driller or journeyman
responsible for sitework if different from permittee)

B 1	2142	SEQUENCE NO. (MDE USE ONLY)	STATE OF MARYLAND APPLICATION FOR PERMIT TO DRILL WELL please type	STATE PERMIT NUMBER <u>HO - 95 - 2100</u>
Date Received (APA)		LOCATION OF WELL B 3 <u>Howard</u> COUNTY <u>Chelsea</u> knoll 23 SUBDIVISION <u>5</u> SECTION <u>44</u> LOT <u>48</u> <u>mt Airy</u> NEAREST TOWN MILES FROM TOWN (enter 0 if in town) <u>4</u>		
OWNER INFORMATION 8 MM DD YY 13 <u>Elm Street Development</u> 15 Last Name <u>Owner</u> First Name <u>34</u> <u>1355 Beverly Rd, Suite 240</u> 36 Street or RFD <u>55</u> <u>McClean, VA 22101</u> 57 Town <u>70</u> State <u>72</u> Zip <u>76</u>		DRILLER INFORMATION <u>Michael Barlow</u> M W D <u>355</u> Driller's Name <u>76</u> License No. <u>81</u> <u>Barlow Well Drilling Service</u> Firm Name <u>522 Underwood Ln, Belair, Md</u> Address <u>[Signature]</u> <u>3-8-11</u> Signature Date		
WELL INFORMATION B 2 1 2 APPROX. PUMPING RATE <u>5</u> (GAL. PER MIN.) <u>8</u> <u>12</u> AVERAGE DAILY QUANTITY NEEDED <u>750</u> (GAL. PER DAY) <u>14</u> <u>20</u>		DIRECTION OF WELL FROM TOWN (CIRCLE BOX) ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX) NEAR WHAT ROAD <u>Long Corner Rd</u> DISTANCE FROM ROAD <u>450</u> FT ENTER FT OR MI <u>38</u> <u>39</u> TAX MAP: <u>6</u> BLK: <u>22</u> PARCEL <u>9</u>		
USE FOR WATER (CIRCLE APPROPRIATE BOX) <input checked="" type="radio"/> D DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION <input type="radio"/> F FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) <input type="radio"/> I INDUSTRIAL, COMMERCIAL, DEWATERING <input type="radio"/> P PUBLIC WATER SUPPLY WELL <input type="radio"/> T TEST, OBSERVATION, MONITORING <input type="radio"/> G GEO-THERMAL		NOT TO BE FILLED IN BY DRILLER HEALTH DEPARTMENT APPROVAL <u>Howard</u> COUNTY NAME <u>(13)</u> COUNTY NO. <u>A 515039</u> STATE SIGNATURE _____ INSERT S → _____ DATE ISSUED <u>4/25/11</u> CO SIGNATURE <u>[Signature]</u> EXP. DATE <u>4/25/12</u> NORTH GRID <u>540 000</u> EAST GRID <u>0756 000</u> 50 55 57 63		
APPROXIMATE DEPTH OF WELL <u>250</u> FEET APPROXIMATE DIAMETER OF WELL <u>6</u> INCH METHOD OF DRILLING (circle one) BORED (or Augered) <input type="radio"/> JETTED <input type="radio"/> Jetted & DRIVEN 30 AIR-ROTary <input type="radio"/> AIR-PERcussion <input checked="" type="radio"/> ROTARY (Hydraulic Rotary) 37 CABLE <input type="radio"/> REVerse-ROTary <input type="radio"/> DRive-POINT other _____		SHOW MAJOR FEATURES OF BOX & LOCATE WELL WITH AN X SOURCES OF DRILLING WATER 1. <u>Well</u> 2. _____ 3. _____ WRITE THE BOX NUMBER FROM THE MAP HERE E <u>7506</u> N <u>53040</u> DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEAREST ROAD JUNCTION 		
REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) <input checked="" type="radio"/> N THIS WELL WILL NOT REPLACE AN EXISTING WELL <input type="radio"/> Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED 39 <input type="radio"/> S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS <input type="radio"/> D THIS WELL WILL DEEPEAN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPEANED (IF AVAILABLE) 41 _____ 52 _____		Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER <u>HO 20 07G 005 (3)</u> PERMIT No. <u>HO - 95 - 2100</u> 70 71 72 73 74 75 76 77 78 79		
SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED				




MICHAEL BARLOW WELL DRILLING & SERVICE, INC.
522 Underwood Lane **Bel Air, Maryland 21014**
 (410) 838-6910 Fax (410) 838-3582

WELL YIELD REPORT

Date Test Completed:		July 29, 2011	
Well Depth:		475	feet
Customer	Elm Street Development	Permit #	HO-95-2100
Road	Long Corner Road	Subdivision	Chelsea Knolls
City	Mt. Airy	Section	
State	Maryland	Lot #	5

Time	Water Level feet	Time to Fill 1-gallon bucket seconds	G.P.M.
7:00 AM	51	4	15.00
7:15 AM	137	4	15.00
7:30 AM	218	5	12.00
7:45 AM	250	15	4.00
8:00 AM	256	20	3.00
8:15 AM	256	20	3.00
8:30 AM	256	20	3.00
8:45 AM	256	20	3.00
9:00 AM	256	20	3.00
9:15 AM	256	20	3.00
9:30 AM	256	20	3.00
9:45 AM	256	20	3.00
10:00 AM	256	20	3.00
10:15 AM	256	20	3.00
10:30 AM	256	20	3.00
10:45 AM	256	20	3.00
11:00 AM	256	20	3.00
11:15 AM	256	20	3.00
11:30 AM	256	20	3.00
11:45 AM	256	20	3.00
12:00 PM	256	20	3.00
12:15 PM	256	20	3.00
12:30 PM	256	20	3.00
12:45 PM	256	20	3.00
1:00 PM	256	20	3.00
1:15 PM	256	20	3.00
1:30 PM	256	20	3.00
1:45 PM	256	20	3.00
This yield test report is for informational purposes only. Please note the yield may increase or decrease over time and the GPM indicated above is not a guarantee.			



Bureau of Environmental Health

8930 Stanford Blvd., Columbia, MD 21045

Main: 410-313-2640 | Fax: 410-313-2648

TDD 410-313-2323 | Toll Free 1-866-313-6300

www.hchealth.org

Facebook: www.facebook.com/hocohealth

Twitter: [HowardCoHealthDep](https://twitter.com/HowardCoHealthDep)

Maura J. Rossman, M.D., Health Officer

INTERIM CERTIFICATE OF POTABILITY

Expiration Date – NOVEMBER 13, 2016

May 13, 2016

Homeowner
18335 Chelsea Knolls Drive
Mr. Airy, MD 21771

**RE: Chelsea Knolls, Lot 5
18335 Chelsea Knolls Drive
Building Permit: B15005251
Well Permit: HO-95-2100**

Dear Homeowner:

This is to advise you that the septic system installation and water well construction for the above referenced property have been inspected and approved. Final approval of the septic system was granted on **4/20/2016**. Final approval of the well line connection to the dwelling was granted on **3/23/2016**. The well construction was completed on **8/30/2011**. Water samples were collected on **5/3/2016**.

The water sample results indicate that the water samples submitted for testing were free of coliform and fecal coliform bacteria at the time of sampling and are bacteriologically safe for drinking. This certifies that the initial sampling requirements of COMAR 26.04.04 "Well Regulations" have been met for the water supply system installed under well permit HO-95-2100. Although the submitted sample results are in compliance with COMAR standards, the Health Department does not guarantee water supplies.


This Interim Certificate of Potability will expire **six months** from the date of issuance. Submission of a second bacteriological test indicating the water is free of coliform and fecal coliform bacteria is required prior to the expiration date, after which time a Final Certificate of Potability will be issued. **Failure to submit an additional sample and obtain a Final Certificate of Potability will result in a Notice of Violation and is punishable as a misdemeanor under the Annotated Code of Maryland, Environment Article, 9-1311, subject to a fine of up to \$500 or imprisonment not to exceed three months.**

Please contact (410) 313-1773 to schedule a final water sample appointment or contact a Maryland certified water laboratory to schedule a water sample. A list of laboratories certified by the state of Maryland may be found at the following website:

<http://www.mde.state.md.us/assets/document/WSP-Labs-2010apr16.pdf>

In closing, please refer to our "[Homeowner Fact Sheet](#)" which illustrates a better understanding for your Best Available Technology (BAT). You will also find a link to Maryland Department of the Environments website which describes in further detail operation and maintenance of your BAT.

Approving Authority,

A handwritten signature in black ink, appearing to read "K. M. Wolf", written over a horizontal line.

Kevin M. Wolf, L.E.H.S., REHS/RS, Supervisor
Groundwater Management Section
Well & Septic Program

cc: Howard County Dept. of Inspections, Licenses, and Permits
Community Hygiene Program
File

**HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
WELL & SEPTIC PROGRAM
TEL: (410)313-1771 FAX: (410)313-2648**

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: Robert L. Feezer Co. Telephone #: 410-781-4655
Address: 6321 Barnett Avenue
Sykesville, MD 21784

(Must circle one) Licensed Plumber Licensed Well Driller Licensed Well Pump Installer
License # and name of individual responsible for the field installation:

Name (Print): Joshua Henricks License# PI0173

***A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.**

Name of Property Owner: Chelsea Knolls LC Telephone #: _____
Subdivision: Chelsea Knolls Lot #: 5 Well Tag #: HO - 95 - 2100
Site Address: 18335 Chelsea Knolls Drive
Mount Airy, MD 21771

Submersible Pump Data

Make: Grundfos
Model #: 10SQE15-330
Pump Capacity 10 GPM
Well Yield: 3.00 GPM

Pitless Adapter

Make: Boshart
Model#: P-100-SS
Depth: 42" (36" min)
NSF/WSC approved: Yes

Well Cap and Electric Conduit

Two piece watertight cap: Yes
Screened, vented well cap: Yes
Cap secured to casing: Yes
Conduit min 18" B.G.: Yes

Depth of well encountered at time of pump installation: 475 (feet) Conduit secured to well cap: Yes

If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4

Torque arrestors, Cable guards, or other acceptable method used- Must circle one

Safety rope, if used, attached to brass rope adapter or other acceptable method inside of well casing N/A

Piping to house

Type: Poly
PSI: 200 (160 psi min)
Depth of supply line: 42" (36" min)

House Connection

PVC sleeve to undisturbed soil at wall penetration: Yes
Length of sleeve(5' minimum from foundation): 10'
Sleeve sealed properly: Yes

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

Joshua Henricks October 15, 2014
Signature of company representative responsible for installation date

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: 3/23/16 Date Insp. Approved: 3/23/16 Inspector: SC
Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade ✓
Two piece cap installed and attached to casing securely ✓
Elec. conduit extends at least 18" below grade/attached to cap properly ✓
Safety rope not outside of well cap/casing ✓
Correct well tag attached properly and casing 8" above finished grade ✓
Water supply line sleeved adequately at house connection ✓
Adequate grout observed below pitless adapter ✓

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 107088 Account #: 6488
Reference: Chelsea Knolls Lot 5 Company: Hatfield's Equipment, Inc.
Location: 18335 Chelsea Knolls Drive Requested By: Kenny Hatfield
Mount Airy, MD 21771 Source: Well Water
Date/ Time Collected: 5/3/2016 1030 Site: Pressure Tank
Date/Time Rec'd: 5/3/2016 1425 Treatment: Prior to Reverse Osmosis
Chlorine ppm: Free: ND Total: ND pH: 6.4
Collected By: T. Frazier 3126TF Well #: HO-95-2100

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	5/4/2016 / 0850 / LLO
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	5/4/2016 / 0850 / LLO
Nitrate	4.40	mg/L	10	601	5/4/2016 / 1230 / CRS
Turbidity	2.05	NTU	<10	SM18 2130B	5/4/2016 / 1250 / CRS
Sand	NS	mg/L	5	Visual/Gravimetric	5/4/2016 / 1250 / CRS

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 NS = None Seen (NS indicates less than 5 mg/L)
- 4 NTU = Nephelometric Turbidity Units
- 5 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 6 ND:None Detected
- 7 Visual well check: Sealed, vented cap
- 8 pH & Chlorine level tested on site

Reason for Test : Use & Occupancy
Building Permit # : 15005251



Date Reported: 5/4/2016

CHELSEA KNOLLS DRIVE
PUBLIC ACCESS STREET (50' ROW)

4-21-11
Well Box staked
by MBA.

KMW

LEGEND

-  WELL AREA
-  SEPTIC AREA

WELL PERMIT CHELSEA KNOLLS LOT 5

FOURTH ELECTION DISTRICT HOWARD COUNTY, MARYLAND

SCALE: 1"=50' DRAWN BY: MMM DATE: APRIL 2011 PN: 01-009

**MILDENBERG
BOENDER, & ASSOC., INC.**

Engineers Planners Surveyors
6800 Deeppath Road, Suite 150, Elkridge, Maryland 21075
(410) 997-0296 Ball. (410) 997-0298 Fax.