

Bureau of Environmental Health
7178 Gateway Drive Columbia, MD 21046
(410) 313-2640 Fax (410) 313-2648
TDD (410) 313-2323 Toll Free 1-866-313-6300
website: www.hchealth.org

Peter L. Beilenson, M.D., M.P.H., Health Officer

January 25th, 2010

MEMORANDUM

TO: Land Design & Development, Inc
Attn: Debbie Zile
Faxed to 443-367-0420

FROM: Kevin Wolf, Environmental Sanitarian
Bureau of Environmental Health
Well and Septic Program

RE: 4635 Ilchester Road
Ellicott City, MD 21043
Map 31, Grid 5, Parcel 623 5.000 AC
(Demolition of Existing House)

KW

*443 367
64122*

This is to advise that the Howard County Health Department recommends issuance of the demolition permit for the above referenced property.

The well, which previously served the existing dwelling, has been disconnected and abandoned/sealed. Abandonment form submitted by licensed well driller. The septic system tank that was currently being used on the above aforementioned property, has been properly abandoned; i.e. pumped, collapsed and filled in with clean fill. This may be completed during the demolition phase if not already completed.

If any other wells or septic systems are found during site work, please notify this office immediately.

Cc: File

Filed to Ron Green w/ Land Design on 4/15/10

- KW

Land Design & Development, Inc.

January 18, 2010

A1984
P 20747

FAX NO.: 410-313-2648

MEMO TO: Sarah Sappington
Health Department

FROM: Debbie Zile
Land Design and Development

RE: 4635 Ilchester Road
Ellicott City, MD 21043

Land Design and Development is going to demolish the above home. The well and septic has been abandoned. Attached you will find a letter from Michael Barlow Well Drilling Contractors dated January 18, 2010 showing the well and septic has been abandoned. Could you please fax me your letter as soon as possible so I can file the permit!

Please issue a demo letter. This letter can be faxed to 443-367-0420. If there are any issues with issuing this letter, please call Debbie Zile at 443-367-0422 ext. 243.

Thank you for all your help!

Debbie Zile

Subdivision
Ellicott City
F-08-071
FSW

ASSOCIATED EXCAVATORS CONTRACTORS
16657 FREDERICK ROAD
MT. AIRY, MD 21771
(410) 442-1886 FAX (410) 442-0100

January 26, 2010

Howard County Health Department
C/o Sarah Sappington
7178 Columbia Gateway Drive
Columbia, MD 21045

Dear Ms. Sappington:

This letter is to inform you that my company performed the abandonment of the septic and drywell located at 4635 Ilchester Road Elkridge, Maryland 21075.

Please see the attached drawing.

If you have any questions please call me at (410) 977.2216.

Thank you,

Mike Johnson

Cc: Mr. Ron Green, Land Design & Development, Inc.

 WATER WELL ABANDONMENT-SEALING REPORT FORM

SUBMIT COPIES OF COMPLETED FORM TO:

- * COUNTY ENVIRONMENT AGENCY (contact MDE, WMA if address needed)
- * WELL OWNER
- * MDE, WATER MANAGEMENT ADMINISTRATION, WELL PROGRAM

DATE WELL ABANDONED: 1/18/2010 (month/day/year)

* PERMIT NUMBER OF ABANDONED WELL (if any) Ho - 73 - 0833


* PERMIT NUMBER OF REPLACEMENT WELL _____

* PERSON ABANDONING WELL: Marty Dixon
LAND Design + Developmat

WELL DRILLERS LICENSE NUMBER: ddo
 CIRCLE: MWD/MSD/MGD

* WELL LOCATION:
 COUNTY: HOWARD
 NEAREST TOWN: Columbia
 TAX MAP _____ BLOCK _____ PARCEL _____
 SUBDIVISION: _____
 SECTION: _____ LOT: _____
 NEAREST ROAD: 4635 Ilchester Rd

SITE LOCATION MAP



* TYPE OF WELL BEING ABANDONED:

DRILLED _____ JETTED
 _____ BORED/AUGERED _____ HAND DUG
 _____ OTHER (specify) _____

* USE CODE:

DOMESTIC _____ MUNICIPAL/PUBLIC
 _____ IRRIGATION _____ INDUSTRIAL
 _____ TEST/OBSERVATION _____ GEOTHERMAL

* TYPE OF CASING:

_____ STEEL _____ PLASTIC
 _____ CONCRETE _____ OTHER (specify) _____

* SIZE OF CASING: 6 INCHES IN DIAMETER

* DEPTH OF WELL: 200 FEET DEEP

* WAS ANY CASING REMOVED? _____ YES NO
 if yes, length removed, in feet: _____

* WAS CASING RIPPED OR PERFORATED? _____ YES NO

LOG OF SEALING MATERIAL

MATERIAL	FEET	
	FROM	TO
Bentonite clay	200	0
VOLUME OF MATERIAL USED		

SIGNATURE - MASTER WELL DRILLER OR SUPERVISING SANITARIAN

LICENSE #

ddo MWD/MSD/MGD

DATE

well

