



INDICATE NORTH. - NAME ADJOINING ROADWAY AS BASE LINE.

JULY WAY

PERMIT CARD

SEPTIC TANK, LEVEL 2000 GAL

CLEANOUTS  15

DISTRIBUTION BOX, LEVEL

TILE FIELD, DEPTH 4' FT. TRENCH WIDTH 3 FT. INLET 3.0

GRAVEL DEPTH 12 IN. TOTAL LENGTH 195 FT.

NUMBER OF TRENCHES 2 TOTAL BOTTOM AREA 585 ~~sq~~

SEEPAGE PITS, INSIDE DIAMETER      FT. DEPTH BELOW INLET      FT.

ABSORBENT AREA 585 SQ. FT.

REMARKS 12/18/85 - ROCK AT 7'-8' -> CHANGE SYSTEM TO SHALLOW TRENCH 3' WIDE INLET 3"  
BOTTOM 4' - 1 FT STONE BELOW PIPE; 193 FT TRENCH NEEDED. S. Abel

DATE SYSTEM APPROVED 12/19/85

INSPECTOR S. Abel