

B 1 00742 SEQUENCE NO. (DP USE ONLY) (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)

STATE OF MARYLAND APPLICATION FOR PERMIT TO DRILL WELL please print or type

STATE PERMIT NUMBER 40-92-0110 fill in this form completely

Date Received (APA) 05/18/92 OWNER INFORMATION Last Name: MAFFIN, Owner: MAFFIN, First Name: RICHARD, Street or RFD: 10000, Town: FULTON, State: 70, Zip: 21539

B 3 LOCATION OF WELL B COUNTY: BALTO, 23 SUBDIVISION: FOUNTAIN VIEW, SECTION: 4, LOT: 12C 11, 52 NEAREST TOWN: FULTON, MILES FROM TOWN: 2 MI

DRILLER INFORMATION Driller's Name: Joseph B. Mayne, License No. 238, Firm Name: Joseph B. Mayne Well Drilling, Address: 5512 Ridge Rd. Mt. Airy, Md. 21771, Signature: Joseph B. Mayne, Date: 5/18/92

B 4 DIRECTION OF WELL FROM TOWN (CIRCLE BOX): NW, NE, SW, SE, S, N, E, W. NEAR WHAT ROAD: KENDRICK DRIVE. ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX): WEST. DISTANCE FROM ROAD: 25 FT. ENTER FT or MI: FT

B 2 WELL INFORMATION APPROX. PUMPING RATE (GAL. PER MIN.): 5, AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY): 500

NOT TO BE FILLED IN BY DRILLER HEALTH DEPARTMENT APPROVAL A17718 COUNTY NAME: Howard, COUNTY NO.: A-2338, STATE SIGNATURE: DATE ISSUED: 070192, CO SIGNATURE: Dave E. Madcan, 1-1-93, NORTH GRID: 476000, EAST GRID: 0815000


USE FOR WATER (CIRCLE APPROPRIATE BOX) HOME (SINGLE OR DOUBLE HOUSEHOLD UNIT ONLY) [X], FARMING-LIVESTOCK WATERING & AGRICULTURAL IRRIGATION), INDUSTRIAL, COMMERCIAL, STATE AND FEDERAL GOV. OTHER (REQUIRES APPROPRIATION PERMIT), PUBLIC OR PRIVATE WATER COMPANY (REQUIRES APPROPRIATION PERMIT AND STATE HEALTH DEPARTMENT APPROVAL), TEST, OBSERVATION, MONITORING (MAY REQUIRE APPROPRIATION PERMIT)

APPROXIMATE DEPTH OF WELL: 300 FEET, APPROXIMATE DIAMETER OF WELL: 6 INCH NEAREST INCH

SHOW MAJOR FEATURES OF BOX & LOCATE WELL WITH AN X: 7/13/92. SOURCES OF DRILLING WATER: 1. WELL, 2., 3. WRITE THE BOX NUMBER FROM THE MAP HERE: 816, 4706

METHOD OF DRILLING (circle one) BORED (or Augered), JETTED, Jetted & DRIVEN, AIR-ROTARY, AIR-PERCussion, ROTARY (Hydraulic Rotary), CABLE, REVerse-ROTary, Drive-POINT, other

REPLACEMENT OR DEEPEMED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL [X], THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED, THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY, THIS WELL WILL DEEPEN AN EXISTING WELL. PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPEMED (IF AVAILABLE):



Not to be filled in by driller (OEP USE ONLY) APPROX. PERMIT NUMBER: GAP, FORCE: IN, PERMIT No.: 40-92-0110

SPECIAL CONDITIONS: NOT TO BE DRILLED... COUNTY

of
7/13/92

FIELD DATA SHEET
HOWARD COUNTY WELL YIELD TEST

Well Permit No. HO - 92-0110
 Location of property (road) Kendrup Drive
 Subdivision Beaufort Park Lot 12 Block C Plat _____ Sec. 4
 Well Driller Joseph Mhyme Owner H Daffer, Robert A.

Depth of well 340'
 Distance of measuring point (M.P.) above ground 3'
 Static water level (S.W.L.) below M.P. 37'

I. High rate pumping -- reservoir drawdown

Time pump started 7:30 Pumping rate 15 gpm.
 Total time 30 min. to reach pumping water level 270 ft below M.P.

II. Recovery pump test data - observations to be recorded every 15 minutes

TIME (in 15 minute intervals)	WATER LEVEL below M.P.	PUMPING RATE time to fill 5/1 gallon bucket	FLOW METER READING (if used)	CALCULATED FLOW (gallons per minute)
7:45	159'	4 sec.		15 gpm.
8:00	270	4		15
8:15	266	60		1
8:30	262	60		1
8:45	262	43		1.3
9:00	262	42		1.3
9:15	262	43		1.3
9:30	262	43		1.3
9:45	259	43		1.3
10:00	259	35		1.7
10:15	259	35		1.7
10:30	260	35		1.7
10:45	261	35		1.7
11:00	262	35		1.7
11:15	263	40		1.5
11:30	262	40		1.5
11:45	261	40		1.5
12:00	241	40		1.5
12:15	261	40		1.5
12:30	261	40		1.5
12:45	261	40		1.5
1:00	260	40		1.5
1:15	260	40		1.5
1:30	259	40		1.5
HD-224 1:45	259	37		1.6
2:00	259	37		1.6

529 gallons over 2 hours

IMPORTANT MESSAGE

TO Ray Hodges

DATE 7/29/92 TIME 11:30 ~~PM~~ A.M.

WHILE YOU WERE OUT

M Gary Christopher

OF Majestic Company

Area Code & Exchange 301 924 2184

TELEPHONED	<input checked="" type="checkbox"/>	PLEASE CALL	<input checked="" type="checkbox"/>
CALLED TO SEE YOU	<input type="checkbox"/>	WILL CALL AGAIN	<input type="checkbox"/>
WANTS TO SEE YOU	<input type="checkbox"/>	URGENT	<input type="checkbox"/>
	RETURNED YOUR CALL	<input checked="" type="checkbox"/>	

Message 7/29/92 Returned

call

Operator 2

IMPORTANT MESSAGE

TO June

DATE 8/3/92 TIME 10:20 ~~AM~~ P.M.

WHILE YOU WERE OUT

M BT Slaffer

OF Beaufort Park Lot 3 11 1/2

Area Code & Exchange _____

TELEPHONED	<input checked="" type="checkbox"/>	PLEASE CALL	
CALLED TO SEE YOU		WILL CALL AGAIN	<input checked="" type="checkbox"/>
WANTS TO SEE YOU		URGENT	
	RETURNED YOUR CALL		

Message This afternoon

Will send a letter stating
Lot 11 to use well on Lot 12
JEN

Operator [Signature]

Howard County Health Department

To: File

Well HO-92-0110 located
on Lot-~~12~~ 12 Beaufort Park
is to serve Lot 11 (A17718).

From: J. Nadeau

Date: 8-18-92

HD-170



THE MAJESTIC CO.

2430 WESTMINISTER DR. OLNEY, MARYLAND 20832
PHONE (301) 924-2184

TO: Howard County Health Department

RE: Well for Lot 11, Block C, Beaufort Park

July 27, 1992

To whom it may concern:

We are the general contractor for the house to be built on the above mentioned lot, owned by Mr. Robert Daffer. This is to inform you of the owner's plans for the well for the above mentioned lot.

The house that is to be built on lot 11 will be serviced by the well that is located on lot 12. Both lots are owned by Mr. Daffer.

The well on lot 12 is a functioning well, permit number HO-92-0110. The building permit number for the house to be built on lot 11 is 44619 (12401 Kondrup Ct., Fulton, MD). The building permit application was filed on July 17 and is still pending.

It is the intention of the owner to file the necessary amendments to the deed to provide for this easement as soon as possible. Hopefully, this will not delay the processing of our permit.

Sincerely,

THE MAJESTIC COMPANY by:

Gary Christopher