

Vawter Property L3243

AP

P-6

dk brn sl, 1/2" blk
red-brn L
2-3 blk common mica
red-brn L
2 musbk
yel-red & pale brn
sl, thin platy
many mica
grey ls, platy
csp (ye-red)
csp (dk brn)
water

P-8

dk grey-brn sl
1/2" blk
brn sl, 1/2" blk
pale brn
& pale yellow
ls, thin platy
10-12% channels
many mica
red-brn ls
platy, many mica
pale brn
ls, thin platy
10-12% channels

P-14

dk grey-brn
sl, 1/2" blk
brn L, 2 blk
red-brn sl
thin platy
common mica
red-brn sl
thin platy
red-vel & pale yellow
ls, platy, many mica
grey ls, water seeps

North

Lot 2

P-7
Pass

P-8
Pass

P-6
Hold

Undulating

P-9
Fail

P-10
Pass

P-11
Pass

P-12
Fail

P-13
Pass

P-14
Fail

Cadonius soil Map unit

P-12

brn sl, 1/2" blk
brn sl, 1/2" blk
many mica
pale brn
& pale yellow
ls, thin platy
10-12% channels
many mica
red-vel
vch ls, thin platy
(spp. lite, dense)
air

P-13

dk brn sl, 1/2" blk
brn chsl, 2 blk
brn sl, 2 blk
yel-red & brn
sl, 2 musbk
many mica
yel-red & pale brn
ls, thin platy
many mica
pale brn ls, dry

34

34

34

34

34

34

34

34

34

34

34

34

34

34

34

34

34

34

34

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
7/7/16	P-6	4.5' / 1.5'	11:08	11:11	11:17	6	H
7/7/16	P-9	4.3' / 1.5'	11:28	1:5	3.2	1.7 min	F
7/7/16	P-8	4.5' / 1.5'	11:51	11:53	11:56	3	P
7/7/16	P-12	3' / 1.3'	12:02	12:05	12:06	—	Report
7/7/16	Repair P-12	3' / 1.3'	12:07:20	12:08:12	12:09:30	1.2	2.95
7/7/16	Repair P-12	3' / 1.3'	12:10:35	12:11:50	12:13:45	1.2	3.5
7/7/16	P-13	4.5' / 1.3'	12:22	12:28	12:32	10	P
7/7/16	P-14	5.3' / 1.8'	12:44	1:14	within 10.7	—	F

REMARKS

SANITARIAN

R Bricker

BACKHOE

Not Ricks

OTHERS

John

TEST HOLES USED IN SDA

AVG. PERC TIME

SQ. FT/BR

TRENCH WIDTH

INLET DEPTH

MAX. BOT DEPTH

EFFECTIVE SW

Vawter Property
Lot 2

AP

P-24

Mixed
Shredded
organic mat.
d rope, decapod
PIC

2.5' olive & grey
L, 0m

3.5' red-brn
to H-brn
thick platy
many mica

4.5' In-brn & red-yel

13' No platy
many mica
10% channers
below 0'

P-25

Mixed
shredded
organic mat.
board
plastic

olive & grey
L, 0m

brn. 2msk

4' H. red-brn
fsl, thick platy
many mica

4' H. red-brn
fsl, platy

to pale brn
fsl, thin platy
many mica
5 to channers

DRIVE WAY

P

P-31

P-24

P-25

P-23
Fail

Stake

Swale
(Fill?)

North

P-23

sh red
organic
material
dk grey brn
L on fsl, 0m

P-31

black
shredded
organic materials
brn. 2msk
red-brn
2msk
red-brn
fsl, thick
platy

4.5' In-brn
red-yel
pale brn
fsl, thin platy
many mica
10% channers

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
7/8/11	P-24	6'10"	1:08	1:11	1:15	4	P
7/8/11	P-25	6'2"	1:23	1:30	1:33	3	P
7/8/11	P-23	4.5'	Visual	Organic fsl	to 5' 2"		F
7/8/11	P-31	6'5"	1:44	1:46	1:49	3	P

REMARKS

Stake P-24 is SDA corner

SANITARIAN

K. Bricker

BACKHOE

Hot Field

OTHERS

John Curry

TEST HOLES USED IN SDA

AVG. PERC TIME

SQ. FT/BR

TRENCH WIDTH

INLET DEPTH

MAX. BOT DEPTH

EFFECTIVE SW

Lots 2 & 3

AP

0.8
2.4
12.8

P-11
dk grey-brn
to brn sl, 1 vlsbk
red-brn sl
2 vlsbk common mica
lt. brn & pale brn
ls, thin plat
many mica
incl. common coarse mica
5%-8% clammers

0.3
1.5
2.2

P-10
dk grey-brn
to brn sl, 1 vlsbk
brn sl, 2 vlsbk
brn & gel-red
chls, thin plat
many mica

11


P-7
pale brn
& red-yel
chls, platy
15% rock
many mica
few clammers & boulders

0.3
1.4
2.4

P-7
dk grey-brn
sl, 1 vlsbk
brn chsl
1 vlsbk
lt. brn & gel-red
chls, thin plat
many mica


11

P-7
red-brn
& pale brn
ls, thin plat
many mica
incl. common coarse mica
few stones



DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
7/7/16	P-11	4'5" / 12.8'	1:25	1:28	1:31	3	P
7/7/16	P-10	4'0" / 11'	1:35	1:37	1:40	3	P
7/7/16	P-7	4'3" / 11'	1:44	1:51	1:54	3	P

REMARKS
SANITARIAN R. Bricker BACKHOE Hot Child's OTHERS John Carney
TEST HOLES USED IN SDA Donnie & Pedro AVG. PERC TIME SQ. FT/BR
TRENCH WIDTH INLET DEPTH MAX. BOT DEPTH EFFECTIVE SW



APPROXIMATE SEWAGE DISPOSAL AREA PER "BRICKER RIDGE" PERC CERT PLAN

LOT 3
N/F
JERRY L. MAUCK AND
JANET C. BURKE
TAX MAP 27 PARCEL 52
LIBER 4749 FOLIO 537
ZONED: RR-DEC

APPROXIMATE SEWAGE DISPOSAL AREA PER "BRICKER RIDGE" PERC CERT PLAN

LOT 2
3.04 AC.
(3.00 MIN.)

LOT 3
3.59 AC.
(3.41 MIN.)

PROPOSED
1500 SF
WELL BOX

APPROX.
HOUSE BOX

PROPOSED
1500 SF
WELL BOX

EXISTING WELL

EXISTING HOUSE TO
REMAIN

LOT 1
3.00 AC.

EX. SEPTIC
TANK

APPROXIMATE
EX. DRY WELL
10' DEEP
8' DIAMETER

PROPOSED
1500 SF
WELL BOX

LOT 10
N/F
JOHN TUCKER
TAX MAP 27 PARCEL 153
LIBER 330 FOLIO 412
ZONED: RR-DEC

COPY
Rec Cert
signed 8/14/17

PAR. B
TURN ESTATES
PARCEL B
NO. 15877
ZONED: RR-DEC

BEISEL
LANA
EL 6'1"
850