

CARROLL WATER SYSTEMS  
60 AILERON COURT, SUITE #3  
WESTMINSTER, MD 21157  
410-876-5100

**HOWARD COUNTY YIELD TEST REPORT**

Date Test Performed: 02-12-18  
Address: 7001 Westcott Place  
Owner Name: Henry Kim  
Well Depth: 300 Ft

Permit Number: HO-88-0273  
Subdivision:  
Election District:  
Static Water Level: 120 Ft

Time	Water Level	PSI Existing Pump	Pumping Rate Seconds to fill 1gallon bucket	Calculated Flow-Gallons Per Minute
1045	120 ft	10 psi	11 sec	5.45
1100	141	10	11	5.45
1115	153	10	11	5.45
1130	156	30	16	3.75
1145	166	38	39	1.54
1200	166	38	39	1.54
1215	166	38	39	1.54
1230	166	38	39	1.54
1245	166	38	39	1.54
1300	166	38	39	1.54
1315	166	38	39	1.54
1330	166	38	39	1.54