
Maura J. Rossman, M.D., Health Officer

MEMORANDUM

TO: Jeff Miller
Home Owner
5808 Trotter Road
Clarksville, MD 21029
05-360226

FROM: **Joseph Cabahug**
Licensed Environmental Health Specialist **001997**
Howard County Health Department
Well & Septic Program

RE: **Sewage Overflow – Existing Drywell**

DATE: May 6th, 2021

JP 05/06/2021

Records indicating remediation for the sewage overflow on 5808 Trotter Road in Clarksville, MD have been submitted to Howard County Health Department.

The scope of the remediation was **temporary abatement, to the satisfaction of Health**, including the replacement of two running fixtures within the house, pumping the existing drywell and septic tank, and affected soil was removed from the steam bank; completed on May 4th, 2021.

The system must be maintained in a functioning condition. If the existing system fails, creating another nuisance condition, Home Owner must immediately apply for an Onsite Waste Water System Repair Permit with Health and the existing system is to be abandoned and sealed. Howard County Health will monitor the conditions of the existing septic system to determine the functioning status of the system. Please note, any future surface discharge nuisance condition will result in a Notice of Violation.