

# FILE INQUIRY NOTES

13719 Tergeo Dr

DATE	RESULTS OF REVIEW FOR FILE
12/12/20	Fogles reports pitless was tight and normal. Pitless
	area flooded with melted snow upon arrival. Sample
	taken by Fogles was sent to lab. (ST)

12/22/2020 Fogles reports pitless was tight and normal. Sample sent to lab. (S)

**Thomas, Susan**

---

**From:** Wolf, Kevin  
**Sent:** Monday, December 21, 2020 3:12 PM  
**To:** Thomas, Susan  
**Subject:** FW: Bacteria

Fyi

----- Original message -----

From: Carrie Condon <Carrie@foglesinc.com>  
Date: 12/21/20 3:02 PM (GMT-05:00)  
To: "Wolf, Kevin" <KWolf@howardcountymd.gov>, "Youmans, Monna" <myoumans@howardcountymd.gov>  
Subject: RE: Bacteria

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Thank you. We will see you tomorrow morning.

**Carrie Condon**  
**Fogle's Well Pump & Water Treatment, LLC**  
**24 HR EMERGENCY SERVICE! 410-795-5670**  
**[www.fogleswellpump.com](http://www.fogleswellpump.com)**  
**"LIKE" us on Facebook!!**

**From:** Wolf, Kevin <KWolf@howardcountymd.gov>  
**Sent:** Monday, December 21, 2020 3:01 PM  
**To:** Carrie Condon <Carrie@foglesinc.com>; Youmans, Monna <myoumans@howardcountymd.gov>  
**Subject:** RE: Bacteria

Ok.

----- Original message -----

From: Carrie Condon <Carrie@foglesinc.com>  
Date: 12/21/20 2:57 PM (GMT-05:00)  
To: "Wolf, Kevin" <KWolf@howardcountymd.gov>, "Youmans, Monna" <myoumans@howardcountymd.gov>  
Subject: RE: Bacteria

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Yes, tomorrow morning 12/22/20

**Carrie Condon**  
**Fogle's Well Pump & Water Treatment, LLC**  
**24 HR EMERGENCY SERVICE! 410-795-5670**  
**[www.fogleswellpump.com](http://www.fogleswellpump.com)**  
**"LIKE" us on Facebook!!**

**From:** Wolf, Kevin <KWolf@howardcountymd.gov>  
**Sent:** Monday, December 21, 2020 2:51 PM  
**To:** Carrie Condon <Carrie@foglesinc.com>; Youmans, Monna <myoumans@howardcountymd.gov>  
**Subject:** RE: Bacteria

Tomorrow morning?

----- Original message -----

**From:** Carrie Condon <Carrie@foglesinc.com>  
**Date:** 12/21/20 2:50 PM (GMT-05:00)  
**To:** "Wolf, Kevin" <KWolf@howardcountymd.gov>, "Youmans, Monna" <myoumans@howardcountymd.gov>  
**Subject:** RE: Bacteria

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Can you please have someone out between 930-1030am to look at the pitless adapter?

**Carrie Condon**  
**Fogle's Well Pump & Water Treatment, LLC**  
**24 HR EMERGENCY SERVICE! 410-795-5670**  
**[www.fogleswellpump.com](http://www.fogleswellpump.com)**  
**"LIKE" us on Facebook!!**

**From:** Wolf, Kevin <KWolf@howardcountymd.gov>  
**Sent:** Monday, December 21, 2020 12:19 PM  
**To:** Carrie Condon <Carrie@foglesinc.com>; Youmans, Monna <myoumans@howardcountymd.gov>  
**Subject:** Re: Bacteria

Carrie,  
You guys should take the samples. We just want to see the pitless adapter and the surrounding well head. Tomorrow or Wednesday is fine.

Thanks,

Kevin M. Wolf, LEHS, REHS/RS

Groundwater Mgmt. Sec. Supervisor

Well & Septic Program

Howard County Health Department


8930 Stanford Blvd.

Columbia, MD 21045

410-313-2645 (Office)

410-313-2648 (Fax)

[www.hchealth.org](http://www.hchealth.org)



[kwolf@howardcountymd.gov](mailto:kwolf@howardcountymd.gov)

#### CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.

---

**From:** Carrie Condon <[Carrie@foglesinc.com](mailto:Carrie@foglesinc.com)>

**Sent:** Monday, December 21, 2020 12:02 PM

**To:** Youmans, Monna <[myoumans@howardcountymd.gov](mailto:myoumans@howardcountymd.gov)>; Wolf, Kevin <[KWolf@howardcountymd.gov](mailto:KWolf@howardcountymd.gov)>

**Subject:** FW: Bacteria

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Is there a day or time this week that would work for you to come inspect the pitless if we dig it up. We are only open tomorrow and Wednesday. We are planning on being closed Christmas Eve through the new year. Let me know your availability and I will see what we can work out for this homeowner on Tergeo Dr.

**Carrie Condon**

**Fogle's Well Pump & Water Treatment, LLC**

**24 HR EMERGENCY SERVICE! 410-795-5670**

**[www.fogleswellpump.com](http://www.fogleswellpump.com)**

**["LIKE" us on Facebook!!](#)**

**From:** [konnurureddy@gmail.com](mailto:konnurureddy@gmail.com) <[konnurureddy@gmail.com](mailto:konnurureddy@gmail.com)>

**Sent:** Monday, December 21, 2020 11:49 AM



**To:** Carrie Condon <Carrie@foglesinc.com>

**Subject:** Fwd: Bacteria

----- Forwarded message -----

**From:** Youmans, Monna <myoumans@howardcountymd.gov>

**Date:** Mon, Dec 21, 2020, 11:42 AM

**Subject:** Bacteria

**To:** konnurureddy@gmail.com <konnurureddy@gmail.com>

Good morning.

I got your message and then sent an email to the Well & Septic Program.

The supervisor said he got information from Fogle's regarding the chlorination process.

It isn't always easy to determine what the problem is, and they want to rule out a problem with the well. They would like to get a bacteria and turbidity sample from the well head. He wrote:

*They will need to get the well driller to dig up and expose the pitless adapter to do this. They can coordinate with our office when the pitless is exposed so we can come out to inspect but this is where the sample should be taken.*

*If this sample comes back 0 for bacteria, the well is good and the owner can request for a deviation to have a uv light installed.*

The Well & Septic phone number is 410.313.1771.

Wishing you the best.

Monna

Monna Youmans

Community Hygiene Program

**410.313.1773**

