

6117 Thompson Dr.

**Scott, Heidi**

---

**From:** Schaeffer, John  
**Sent:** Wednesday, April 21, 2010 9:15 AM  
**To:** Scott, Heidi  
**Cc:** Welty, Jeff  
**Subject:** RE: public utilities

6117 Thompson Drive is inside the Planned Service Area for public water and sewer. However, it is outside the Metropolitan District and does not front public water and sewer lines; therefore, at this time the lot is not eligible for public water and sewer connections. However, being inside the Planned Service Area, the owner can petition Public Works to enter the Metropolitan District. And, once inside the Metropolitan District the lot owner could negotiate a public water and sewer extension down Thompson Drive. The process could take two years.

**From:** Welty, Jeff  
**Sent:** Wednesday, April 21, 2010 8:17 AM  
**To:** Schaeffer, John  
**Subject:** FW: public utilities

John,

Would you please check this address and get back with Heidi?

Jeff w.

---

**From:** Scott, Heidi  
**Sent:** Tuesday, April 20, 2010 9:17 AM  
**To:** Welty, Jeff  
**Subject:** public utilities

Hi Jeff,

I was told maybe you could help me regarding this. I'm having trouble figuring out if a property at 6117 Thompson Dr. in Clarksville has access to public water and/or sewer. Would you have this information? Thanks.

Heidi Scott  
Howard County Health Dept.  
Well & Septic Program  
410-313-6287

HOWARD COUNTY HEALTH DEPARTMENT  
BUREAU OF ENVIRONMENTAL HEALTH  
WATER AND SEWERAGE PROGRAM  
TEL: (410)313-2640 FAX: (410)313-2648

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: \_\_\_\_\_ Telephone #: \_\_\_\_\_  
Address: \_\_\_\_\_

(Must circle one) Licensed Plumber      Licensed Well Driller      Licensed Well Pump Installer  
License # and name of individual responsible for the field installation:

Name (Print): \_\_\_\_\_ License# \_\_\_\_\_

**\*A licensed individual must perform the actual installation. Apprentices must be under the direct supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification.**

Name of Property Owner: \_\_\_\_\_ Telephone #: \_\_\_\_\_  
Subdivision: \_\_\_\_\_ Lot #: \_\_\_\_\_ Well Tag #: HO - \_\_\_\_\_  
Site Address: 6117 Thompson Drive

Submersible Pump Data

Make: \_\_\_\_\_  
Model #: \_\_\_\_\_  
Pump Capacity \_\_\_\_\_ GPM  
Well Yield: \_\_\_\_\_ GPM

Pitless Adapter

Make: \_\_\_\_\_  
Model#: \_\_\_\_\_  
Depth: \_\_\_\_\_ (36" min)  
NSF approved: \_\_\_\_\_

Well Cap and Electric Conduit

Two piece watertight cap: \_\_\_\_\_  
Screened, vented well cap: \_\_\_\_\_  
Cap secured to casing: \_\_\_\_\_  
Conduit min 18" B.G.: \_\_\_\_\_  
Conduit secured to well cap: \_\_\_\_\_

Depth of well encountered at time of pump installation: \_\_\_\_\_ (feet)  
If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4

Torque arrestors or Cable guards are required - Must circle one

Safety rope, if used, attached to inside of well casing with eye bolt \_\_\_\_\_

Piping to house

Type: \_\_\_\_\_  
PSI: \_\_\_\_\_ (160 psi min)  
Depth of supply line: \_\_\_\_\_ (36" min)

House Connection

PVC sleeved to undisturbed soil at wall penetration: \_\_\_\_\_  
Approximate length of sleeve: \_\_\_\_\_  
Sleeve caulked and sealed properly: \_\_\_\_\_

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

Signature of company representative responsible for installation \_\_\_\_\_ date \_\_\_\_\_

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: \_\_\_\_\_ Date Insp. Approved: \_\_\_\_\_  
Inspection Data: Pitless adapter and water supply line at least 36" below grade  
Two piece cap installed and attached to casing securely  
Elec. conduit extends at least 18" below grade/attached to cap properly  
Safety rope installed inside of well casing  
Correct well tag attached properly and casing 3" above finished grade  
Water supply line sleeved adequately at house connection  
Adequate grout observed below pitless adapter

*O.K except no grout (BB)*  
*6/7/2010*  
*No Tag*  
*Connected to Existing Line*  
*Doesn't Appear*  
*Grouted -*