

C1 0579 SEQUENCE NO. (DENV USE ONLY)
(THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)

STATE OF MARYLAND
WELL COMPLETION REPORT
FILL IN THIS FORM COMPLETELY
PLEASE PRINT OR TYPE

THIS REPORT MUST BE SUBMITTED WITHIN
45 DAYS AFTER WELL IS COMPLETED.

COUNTY
NUMBER

A36514

ST/CO USE ONLY

DATE Received

8 13

DATE WELL COMPLETED

100893

Depth of Well

22 180 26
(TO NEAREST FOOT)

PERMIT NO.

FROM "PERMIT TO DRILL WELL"

40-92-0461

OWNER Daub last name Triandolphia first name Rd TOWN Glenolo
STREET OR RFD WAYSIDE SUBDIVISION MANAR SECTION LOT 2

WELL LOG

Not required for driven wells

STATE THE KIND OF FORMATIONS
PENETRATED, THEIR COLOR, DEPTH,
THICKNESS AND IF WATER BEARING

DESCRIPTION (Use
additional sheets if needed)

FEET
FROM TO

Check
if water
bearing

SAND Stone 0 43

GRAY mica
Rock 43 180

380' - 250'
2 dry wells Filled in
with cement &
drilling materials

GROUTING RECORD

WELL HAS BEEN GROUTED
(Circle Appropriate Box)

YES ☒ NO ☐

TYPE OF GROUTING MATERIAL

CEMENT ☒ BENTONITE CLAY ☐

NO. OF BAGS 12 NO. OF POUNDS 1100

GALLONS OF WATER 72

DEPTH OF GROUT SEAL (to nearest foot)

from 0 ft. to 40 ft.
(enter 0 if from surface)

CASING RECORD

casing
types
insert
appropriate
code
below

ST CO
STEEL CONCRETE
PL OT
PLASTIC OTHER

MAIN
CASING
TYPE

Nominal diameter
top (main) casing
(nearest inch)

Total depth
of main casing
(nearest foot)

51

6

47

EACH
CASING

OTHER CASING (if used)
diameter inch from to

screen type
or open hole

SCREEN RECORD

insert
appropriate
code
below

ST BR HO
STEEL BRASS OPEN
HOLE
PL OT
PLASTIC OTHER

C2

EACH
SCREEN

DEPTH (nearest ft.)

1 11 0 45 15 17 180 21
2 23 24 26 30 32 36
3 38 39 41 45 47 51

SLOT SIZE 1 2 3

DIAMETER OF SCREEN (NEAREST INCH)

from to

GRAVEL PACK
IF WELL DRILLED WAS
FLOWING WELL INSERT
F IN BOX 68

OEP USE ONLY
(NOT TO BE FILLED IN BY DRILLER)

T (E.R.O.S.) W Q
70 72 74 75 76

TELESCOPE CASING LOG INDICATOR OTHER DATA

C3

PUMPING TEST

HOURS PUMPED (nearest hour) 3

PUMPING RATE (gal. per min. to nearest gal.) 15

METHOD USED TO MEASURE PUMPING RATE

WATER LEVEL (distance from land surface)

BEFORE PUMPING 24

WHEN PUMPING 41

TYPE OF PUMP USED (for test)

A air P piston T turbine
C centrifugal R rotary O other (describe below)
J jet S submersible

PUMP INSTALLED

DRILLER WILL INSTALL PUMP YES NO

(CIRCLE) (YES or NO)
IF DRILLER INSTALLS PUMP, THIS SECTION
MUST BE COMPLETED FOR ALL WELLS

EXCEPT HOME USE

TYPE OF PUMP INSTALLED

PLACE (A,C,J,P,R,S,T,O)

IN BOX - SEE ABOVE:

CAPACITY:

GALLONS PER MINUTE (to nearest gallon)

PUMP HORSE POWER

PUMP COLUMN LENGTH (nearest ft.)

CASING HEIGHT (circle appropriate box and enter casing height)

above below

LAND SURFACE (nearest foot)

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS
BUILDING, SEPTIC TANKS, AND/OR
LANDMARKS AND INDICATE NOT LESS
THAN TWO DISTANCES
(MEASUREMENTS TO WELL)

See attached
location

CIRCLE APPROPRIATE LETTER

A A WELL WAS ABANDONED AND SEALED
WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION
WELL

I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN
ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION"
AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE
ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRE-
SENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF
MY KNOWLEDGE.

DRILLERS IDENT. NO. 36

DRILLERS SIGNATURE
(MUST MATCH SIGNATURE ON APPLICATION)

SITE SUPERVISOR (sign. of driller or journeyman
responsible for sitework if different from permittee)

COUNTY

Well Permit No. HO - 92-0461
Location of property (road) Triadelphia Rd
Subdivision WAYSIDE MANOR Lot 3 Block Plat Sec.
Well Driller J Mayne Owner Danb, R W and Danb Cecilia
Depth of well 180
Distance of measuring point (M.P.) above ground 2'
Static water level (S.W.L.) below M.P. 24'

Time pump started 10:50 Pumping rate 15 gpm
Total time 15 min to reach pumping water level 41 ft. below M.P.

[illegible]

RECEIVED

MAY 24 1994

LICENSES & PERMITS
DIVISION

Corbin,

May 24, 1994
~~RASAR~~

I have revised the house elevation and ~~the~~ modified the sewage disposal easement to accommodate the required septic system as per requirements of Mr. Craig Williams of the Health Dept. I have also added septic system details and data to the plan.

I have not in any way adjusted or changed the house footprint in making the above changes.

Thanks for your assistance in this matter.

Sincerely
Wes Dault

P.S. The building address is

12735 Triadelphia Rd.
Ellicott City, Md.
21045

~~Permit No. SA115~~

~~cc: Health Dept.~~
Plan - Review

MATCHES APPROVED SITE PLAN
RECEIVED 5/24/94