8/9-95 8/30/CP

PERMIT

05-40714

SEWAGE DISPOSAL SYSTEM

A 38570

P 50728

DEPARTMENT OF HEALTH AND MENTAL HYGIENE

DISTRICT 5th

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

XX61X99XXX 313-2640

INDEXED

DATE 6-7-95

DATE SYSTEM APPROVED 8/9/95

INSPECTOR DIS

South Carroll Backhoe, Inc. IS PERMITTED TO INSTALL X ALTER
ADDRESS 4410 Salem Bottom Road, Westminster, Maryland 21157 PHONE 875-4197
SUBDIVISION Twelve Hills, Sec. 2 LOT 12 ROAD 13008 Twelve Trees Court
PROPERTY OWNER Craig A & Anne Rosenstein
ADDRESS
SEPTIC TANK CAPACITY 1250 GALLONS PERMIT SIGNED
NUMBER OF BEDROOMS 4 STURNED 9-15-99
180 SOLIABE ELET DED DEDDOOM Serial #Bro 120412
LINEAR FEET OF TRENCH REQUIRED 144
TRENCHES - Trench to be 2 feet wide. Inlet 3.5 feet below original grade. Bottom maximum
depth 8.5 feet below original grade. Effective area begins at 3.5 feet below
original grade. 5 feet of stone below distribution pipe.
LOCATION - Place distribution box 215 feet up the right lot line (284.73) and 35 feet off
that same lot line as seen when facing the lot from Twelve Trees Court. Run
trenches on contour in both directions.
NOTES - No trench to exceed 100 feet in length. Provide 6" - 8" diameter cleanout and cap to grade or above on septic tank. OL Pun 5-25-95
cap to grade or above on septic tank. or pun \$-15-98
GEDG PLRMIT SIGNED
REVIEWED 10-22-99
PLANS APROVED BY Amy McMillen Squal # Bt 0/2/063 DATE 05/02/95
COVER NO WORK UNTIL INSPECTED AND APPROVED
NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM
NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS NOT ACCEPTABLE.
NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)
NOTE: IF DEEP TRENCH(ES) ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH(ES)
NOTE: NO DRY WELL SHALL SYCEED AS SOOT IN DIAMSTED NO ARSORPTION TRENCH TO SYCEED AN ESET IN LENGTH BLUG. PERMIT SIGNED
NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS SERVAL # BOOLOO LILYT
PERMIT VOID AFTER TWO YEARS 1300100 2447

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON. CONCRETE OR TERRA COTTA OR PVA OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET. MANHOLE TO GRADE-REQUIRED.

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES



