

Twist & Turn ^{ESTATBS} Lot 7**FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.**

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #:	67206	Account #:	1930
Reference:	Robert Chew	Company:	Fogle's Well Drilling
Location:	14160 Twisting Lane Dayton, MD 21036	Requested By:	Dave Fogle
Date/ Time Collected:	4/16/2008 0900	Source:	Well Water
Date/Time Rec'd:	4/16/2008 1045	Site:	Kitchen Sink Tap
Chlorine ppm:	Free: ND Total: ND	Treatment:	Reverse Osmosis**
Collected By:	V.M. Fadoul 6804VF-FS	pH:	6.3
		Well #:	HO-94-1213

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Radium-226	0.4	pCi/L	****	903.1	4/28/2008 / 1715 / MJN
Radium-228	<0.9	pCi/L	****	Ra-05	4/25/2008 / 1359 / PJ

NOTES

- 1 ****Radium 226 and Radium 228 combined have a reference of 5 pCi/L
- 2 **Sample collected prior to treatment
- 3 pCi/L = picocuries per liter
- 4 pH tested on-site
- 5 Radium 226 Detection Limit 0.1 pCi/L
- 6 Radium 228 Detection Limit 0.9 pCi/L
- 7 ND:None Detected
- 8 Sample collected by client, analyzed as received
- 9 Subcontracted to Reference Lab #278

Reason for Test : Real Estate

Date Reported: 4/29/2008