

# HOWARD COUNTY HEALTH DEPARTMENT

JOYCE M. BOYD, M.D., M.P.H.  
COUNTY HEALTH OFFICER



Bureau of Environmental Health  
3525 Ellicott Mills Drive  
Ellicott City, Maryland 21043

Director - 461-9950  
Water & Sewerage, Permits - 461-9933  
Community Environmental Health - 461-9944  
Technical Services - 461-9955

February 14, 1989

Mr. Doug Burrill  
15748 Union Chapel Road  
Woodbine, Maryland 21797

RE: Well Tag Number: HO-73-3591  
Parcel "D" Daisy Hill Estates  
15748 Union Chapel Road

Dear Mr. Burrill:

As discussed by telephone, a series of tests of the above referenced well shows a consistent nitrate-nitrogen contaminant level from 10-12 parts per million.

Maryland Well Construction Regulation effective November, 1980 allows approval of new wells only if nitrate-nitrogen content is less than 10 parts per million.

This office strongly advises installation of a nitrate treatment device on this well. However, because this well was permitted and drilled before the effective date of that regulation, no enforcement can be taken for failure to comply with this recommended limit.

This letter is a statement of intentional "No Action" and does not constitute approval of the water supply.

If you have any questions relative to this matter, please call me at 461-9933.

Very truly yours,

Craig Williams, Director  
Water and Sewerage Program

CW:JR

Parcel "E"  
6.1603 Ac.

S42°37'40"W  
481.54

200.00

N22°29'00"E  
405.12

S64°12'30"E  
350.00

Parcel "D"  
6.0395 Ac.

S29°47'30"E  
529.70  
975.27

0.90 Ac.

N23°47'30"E  
154.43

S64°12'30"E  
264.47

N35°06'00"E  
910.00  
635.00

110.00  
50.00  
S64°12'30"E  
160.00

S64°12'30"E  
177.93  
354.67

5.17