



Bureau of Environmental Health
8930 Stanford Blvd | Columbia, MD 21045
410.313.2640 - Voice/Relay
410.313.2648 - Fax
1.866.313.6300 - Toll Free

Maura J. Rossman, M.D., Health Officer

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: J.R. Plumbing + Heat Telephone #: (410) 987-1094
Address: 502 CAPOCK Lane
Sevier, MD 21144

Must circle one: Licensed Plumber / Licensed Well Driller / Licensed Well Pump Installer

License # and name of individual responsible for the field installation:

Name (Print): Chris Pasciano License # #10285

*A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.

Name of Property Owner: Fingles Telephone #: (443) 618-0806

Subdivision: _____ Lot #: _____ Well Tag #: HO - - -

Site Address: 1734 Underwood Road
Sykesville, MD 21154

Submersible Pump Data

Make: _____

Model #: _____

Pump Capacity _____

Well Yield: _____

Depth of well encountered at time of pump installation: _____ (feet)

If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4

Must circle one: Torque arrestors / Cable guards / Other acceptable method used

Safety rope, if used, attached to brass rope adapter or other acceptable method inside of well casing

Pitless Adapter

Make: _____

Model #: _____

GPM Depth: _____ (36" min)

GPM NSF/WSC approved: _____

Well Cap and Electric Conduit

Two piece watertight cap: _____

Screened, vented well cap: _____

Cap secured to casing: _____

Conduit min 18" B.G.: _____

Conduit secured to well cap: _____

Piping to house

Type: 1"

PSI: (160 psi min)

Depth of supply line: (36" min)

House Connection

PVC sleeve to undisturbed soil at wall penetration: ✓

Length of sleeve (5' minimum from foundation): ✓

Sleeve sealed properly: ✓

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

Signature of company representative responsible for installation

date

2/28/24

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: 2/27/24 Date Insp. Approved: 2/28/24 Inspector: SP

Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade ✓ 36'

Two piece cap installed and attached to casing securely ✓

Elec. conduit extends at least 18" below grade/attached to cap properly ✓

Safety rope not outside of well cap/casing ✓

Correct well tag attached properly and casing 8" above finished grade ✓

Water supply line sleeved adequately at house connection ✓ 6'

Adequate grout observed below pitless adapter ✓

(Revised form 10/24/2018)

Website: www.hchealth.org Facebook: www.facebook.com/hocohealth Twitter: @HoCoHealth